

FILE COPY

Circulate

**Environmental
Monitoring Plan**

**Advanced Flue Gas
Desulfurization Project**

Bailly Generating Station

January 1991

FINAL

Area Air on the Lake

FINAL
ENVIRONMENTAL MONITORING PLAN
(EMP)
FOR
BAILLY GENERATING STATION ADVANCED FLUE GAS

SUBMITTED TO
U.S. DEPARTMENT OF ENERGY
PITTSBURGH ENERGY TECHNOLOGY CENTER
P.O. BOX 10940

BY

PURE AIR ON THE LAKE, LIMITED PARTNERSHIP
C/O AIR PRODUCTS AND CHEMICALS, INC.
7201 HAMILTON BOULEVARD
ALLENTOWN, PA 18195-1501

NORTHERN INDIANA PUBLIC SERVICE COMPANY
5265 HOHMAN AVE.
HAMMOND, IN 46320

JANUARY, 1991

PURE AIR, NORTHERN INDIANA

BAILLY GENERATING STATION ADVANCED FLUE GAS
DESULFURIZATION PROJECT

ENVIRONMENTAL MONITORING PLAN
(EMP)

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
1.0 INTRODUCTION	1-1
1.2.2 DURATION OF ENVIRONMENTAL MONITORING	1-2
1.2.3 ENVIRONMENTAL MEDIA AND PARAMETERS	1-2
1.2.4 DATA COLLECTION	1-5
1.3 ORGANIZATION OF EMP	1-5
2.0 PROJECT DESCRIPTION	2-1
2.1 PROJECT PROPONENTS, PURPOSE AND LOCATION	2-1
2.2 PROJECT PHASES	2-5
2.3 PROJECT SCHEDULE	2-5
2.4 PROCESS DESCRIPTION	2-6
2.5 EMISSIONS AND DISCHARGES	2-8
2.5.1 ATMOSPHERIC EMISSIONS	2-8
2.5.3 SOLID WASTES	2-8
2.6.2 WASTEWATER DISCHARGES CONTROL	2-10
2.6.3 SOLID WASTES CONTROL	2-11

TABLE OF CONTENTS (CONTD)

<u>SECTION</u>	<u>PAGE</u>
3.0 EXISTING ENVIRONMENT	3-1
3.1 ATMOSPHERIC RESOURCES	3-1
3.1.2 AIR QUALITY	3-2
3.2.2 SEISMICITY	3-8
3.3 WATER RESOURCES	3-12
3.3.1 GROUNDWATER	3-12
3.3.2 SURFACE WATER	3-16
3.4 ECOLOGICAL RESOURCES	3-18
3.4.1 TERRESTRIAL	3-18
3.4.1.1 VEGETATION	3-20
3.4.1.2 VERTEBRATES	3-22
3.4.2.3 ZOOPLANKTON	3-27
3.4.2.4 PHYTOPLANKTON	3-30
3.5 SOCIOECONOMIC RESOURCES	3-31
3.5.1 POPULATION	3-31
3.5.2 LAND USE	3-33
3.5.2.2 INDUSTRIAL	3-34
3.5.2.3 AGRICULTURAL	3-34

TABLE OF CONTENTS (CONTD)

<u>SECTION</u>	<u>PAGE</u>
3.5.3 PUBLIC SERVICES	3-36
3.5.3.1 SCHOOLS, HOSPITALS AND NURSING HOMES	3-36
3.5.3.2 TRANSPORTATION	3-36
3.5.3.3 HISTORICAL SITES AND NATURAL LANDMARKS	3-41
3.5.3.4 RECREATION	3-42
3.6 ENERGY AND MATERIALS RESOURCES	3-43
3.7 REFERENCES	3-44
4.0 CONSEQUENCES (IMPACTS) OF THE PROJECT	4-1
<hr/>	
4.2 LAND RESOURCES IMPACTS	4-5
<hr/>	
4.3 WATER RESOURCES IMPACTS	4-7
<hr/>	
4.3.1.2 OPERATION	4-7
4.3.2 SURFACE WATER	4-8
4.3.2.1 CONSTRUCTION	4-8
4.3.2.2 OPERATION	4-8
4.4 ECOLOGICAL RESOURCES IMPACTS	4-13
4.4.1 CONSTRUCTION	4-13
4.4.2 OPERATION	4-13

TABLE OF CONTENTS (CONTD)

<u>SECTION</u>	<u>PAGE</u>
4.5.1 CONSTRUCTION	4-14
4.5.1.3 VISUAL	4-15
4.5.2 OPERATION	4-16
4.5.2.1 TRANSPORTATION	4-16
4.5.2.2 NOISE	4-16
4.5.2.3 VISUAL	4-17
4.6 ENERGY AND MATERIALS RESOURCES IMPACTS	4-17
4.6.1 CONSTRUCTION	4-17
4.6.2 OPERATION	4-17
5.3 WATER RESOURCES MITIGATION MEASURES	5-3
5.4 ECOLOGICAL RESOURCES MITIGATION MEASURES	5-4
5.5 SOCIOECONOMIC RESOURCES MITIGATION MEASURES	5-4
6.0 ENVIRONMENTAL MONITORING	6-1
6.1 BASELINE STUDIES (ENVIRONMENTAL CHARACTERIZATION FOR CLASS I MONITORING)	6-14
6.1.1 INTRODUCTION	6-14
6.1.2 ENVIRONMENTAL STUDIES	6-15

TABLE OF CONTENTS (CONTD)

<u>SECTION</u>	<u>PAGE</u>
6.1.3 OPERATING PERFORMANCE TESTS	6-15
6.1.3.1 BAILLY STATION OPERATING CONDITIONS	6-15
6.1.3.2 PROCESS OPERATING CONDITIONS	6-16
6.1.3.3 ENVIRONMENTAL EMISSIONS AND DISCHARGES	6-19
6.1.4 SCHEDULE	6-27
6.1.4.1 DURATION	6-27
6.1.4.2 FREQUENCY	6-28
<hr/>	
6.2.3 MONITORING REQUIREMENTS AND ENVIRONMENTAL MEDIA	6-30
<hr/>	
6.2.3.2 WASTEWATER DISCHARGES	6-34
6.2.3.3 SOLID WASTES	6-40
6.2.4 SCHEDULE	6-41
6.2.4.1 DURATION	6-41
6.2.4.2 FREQUENCY	6-41
<hr/>	
(CLASS III MONITORING)	
6.3.1 INTRODUCTION	6-42
6.3.2 MONITORING PREDICTED IMPACTS	6-42
6.3.3 MONITORING SUCCESS OF MITIGATION MEASURES	6-43
6.3.4 SUPPLEMENTAL MONITORING MEDIA	6-43
6.4 QUALITY ASSURANCE/QUALITY CONTROL PROGRAM	6-44
6.4.1 AIR EMISSIONS MONITORING QA/QC PROGRAM	6-44

TABLE OF CONTENTS (CONTD)

<u>SECTION</u>	<u>PAGE</u>
6.4.2 WASTEWATER DISCHARGES MONITORING QA/QC PROGRAM	6-61
6.4.3 GASES AND SOLID WASTES MONITORING QA/QC PROGRAM	6-62
6.4.4 SOUND LEVEL MONITORING QA/QC PROGRAM	6-63
6.5 INDUSTRIAL HYGIENE MONITORING REQUIREMENTS	6-64
6.5.2 EXPOSURE MONITORING	6-66
<hr/>	
7.0 INTEGRATION OF MONITORING ACTIVITIES	7-1
7.1 INTRODUCTION	7-1
<hr/>	
8.0 DATA MANAGEMENT AND REPORTS	8-1
8.1 DATA MANAGEMENT SYSTEM	8-1
8.2 REPORTING SCHEDULE	8-2
8.3 FORMAT AND CONTENT OF MONITORING REPORTS	8-2
8.3.1 SECTION I OVERVIEW OF CHAPTER ON WATER	8-3
8.3.3 SECTION III SOURCE EMISSIONS AND DISCHARGES	8-4

TABLE OF CONTENTS (CONTD)

SECTION

8.3.3.1	AIR EMISSIONS	8-4
8.3.3.2	WASTEWATER DISCHARGES	8-5
8.3.3.3	SOLID AND SOLID WASTE DISCHARGES	8-6
8.3.3.4	PLANT OPERATING CONDITIONS	8-6
8.3.4	SECTION IV COMPLIANCE	8-6
8.3.5	SECTION V PROBLEMS AND RECOMMENDATIONS	8-7
8.3.6	SECTION VI APPENDICES	8-7
8.4	CONFIDENTIAL INFORMATION	8-7

9.3	PURE AIR	9-2
-----	----------	-----

9.4	STEARNS-ROGER DIVISION OF UNITED ENGINEERS & CONSTRUCTORS, INC.	9-3
-----	--	-----

APPENDIX A BAILLY GENERATING STATION AND AFGD PROJECT
ENVIRONMENTAL PERMITS

LIST OF TABLES

<u>TABLE</u>		<u>PAGE</u>
1.2-1	ENVIRONMENTAL MEDIA AND PARAMETERS TO BE MONITORED	1-3
2.1-1	1988 MONITORING DATA FOR DUNE 22 - ONE MILE WEST OF BAILLY GENERATING STATION	2-8
3.2-1	MODIFIED MERCALLI SCALE	3-9
3.3-1	LAKE MICHIGAN FLOOD ELEVATIONS (NATIONAL GEODETIC VERTICAL DATUM-1929)	3-19
3.4-1	ABUNDANT BIRD SPECIES KNOWN TO NEST IN THE INDIANA DUNES	3-24
3.4-2	FISH SPECIES VERIFIED IN THE AQUATIC COMMUNITY OF THE BAILLY GENERATING STATION VICINITY	3-26
3.5-1	POPULATION DATA FOR INCORPORATED COMMUNITIES WITHIN	3-32
3.5-2	MAJOR MANUFACTURING ACTIVITY WITHIN A 5-MILE RADIUS OF	3-35

LIST OF TABLES (CONTD)

3.5-3 HOSPITALS WITHIN A 12-MILE RADIUS OF THE 3-37
BAILLY GENERATING STATION

4.1-1 BAILLY STATION AND AFGD SYSTEM IDEM, OAM PERMIT 4-3

4.3-1 BAILLY STATION IDEM, OWM PERMIT LIMITS AND WASTEWATER 4-10

DISCHARGES AND PERMIT LIMITS

(CLASS I MONITORING)

6.0-2 COMPLIANCE ENVIRONMENTAL MONITORING 6-10
(CLASS II MONITORING)

6.0-3 SUPPLEMENTAL ENVIRONMENTAL MONITORING 6-13
(CLASS III MONITORING)

6.1-1 BAILLY STATION EXISING STACK IDEM, OAM PERMIT LIMITS 6-17
FOR OPERATION OF AIR POLLUTION CONTROL FACILITIES

LIST OF TABLES (CONTD)

6.1-2	BAILLY STATION PERMIT LIMITS AND MONITORING REQUIREMENTS FOR WASTEWATER DISCHARGES PRIOR TO NPDES PERMIT MODIFICATION	6-18
6.1.3	SOUND LEVEL MONITORING STATIONS	6-21
6.2-1	AFGD SYSTEM IDEM, OAM PERMIT LIMITS FOR CONSTRUCTION	6-31
6.2.2	BAILLY STATION/AFGD SYSTEM PERMIT LIMITS AND MONITORING REQUIREMENTS FOR WASTEWATER DISCHARGES	6-36
6.2-3	POTENTIAL CHEMICAL AND PHYSICAL PARAMETERS TO BE ANALYZED AND ANALYTICAL TECHNIQUES	6-45
6.2-4	SAMPLING METHODS FOR CHEMICAL AND PHYSICAL PARAMETERS TO BE MONITORED	6-47

LIST OF FIGURES

<u>FIGURE</u>		<u>PAGE</u>
2.1-1	BAILLY GENERATING STATION SITE LOCATION MAP	2-2
<hr/>		
2.4-1	AFGD SYSTEM PROCESS FLOW SCHEMATIC	2-7
3.1-1	WINDROSE '84 - '86 DUNE ACRES DATA	3-3
3.2-1	CROSS-SECTION PERPENDICULAR TO THE LAKE MICHIGAN SHORELINE SHOWING GEOLOGY AND GROUNDWATER MOVEMENT NEAR THE BAILLY GENERATING STATION	3-7
3.2-2	SOIL COMPOSITION - BAILLY GENERATING STATION AREA	3-11
3.5-1	MAJOR ROADWAYS AND RECREATIONAL LAND USE	3-40
4.3-1	BAILLY STATION/AFGD SYSTEM WASTEWATER FLOWS	4-11
<hr/>		
7.1-1	BAILLY STATION AFGD PROJECT ORGANIZATION AND	7-2

SECTION 1.0

INTRODUCTION

1.1 PURPOSE OF EMP

Pure Air and the Northern Indiana Public Service Company (Northern

Generating Station. The purpose of the EMP is to (1) provide

the rationale for the scope and types of monitoring that will be

Energy (DOE) on February 16, 1990 and subsequently approved by DOE on

The environmental monitoring activities presented in the EMPO and EMP are based on expected project needs and current regulatory agency

change in regulatory agency requirements change. Therefore, the environmental media sampled, parameters analyzed, sampling and analytical system's demonstration period. This will be reflected in revisions or amendments to the EMP.

1.2 SCOPE

1.2.1 CATEGORIES OF ENVIRONMENTAL MONITORING

However, the project will consider reporting any available off-site ambient air quality monitoring data during the 3-year demonstration period. Monitoring will be primarily for environmental characterization (Class I Monitoring) and compliance (Class II Monitoring) with regulatory agency

project. Because the AFGD system will be operated in accordance with all applicable governmental rules and regulations, there will be minimal supplemental monitoring (Class III Monitoring). The environmental characterization and compliance monitoring will minimize or negate the need for supplemental monitoring. These monitoring activities are described in more detail in Section 6.0 Environmental Monitoring.

1.2.2 DURATION OF ENVIRONMENTAL MONITORING

Environmental characterization monitoring will be performed prior to and during the 3-year demonstration phase of the project. Compliance monitoring will be performed during the 3-year

1.2.3 ENVIRONMENTAL MEDIA AND PARAMETERS

Table 1.2.1 shows the general environmental media and parameters to be monitored as part of the AFGD project. Both the media and parameters are dependent, in part, on the sample location.

DESULFURIZATION PROJECT

ENVIRONMENTAL MEDIA AND PARAMETERS TO BE MONITORED

General/Metals^d, Radioactivity^e

Hydrated Lime

Major Anions, General/Metals, Radioactivity

ASH

General/Metals, Corrosivity, Ignitability, Reactivity, TCLP Test, Indiana Neutral Leaching Method Test, Radioactivity, CaCl₂, Ca(OH)₂, MgCl₂, CaSO₄·2H₂O, CaF₂

Wastewater Treatment

Corrosivity, Ignitability, Reactivity, TCLP Test,

and Grease, Chloride, TDS, Sulfate, Fluoride, BOD₅, pH, Calcium, Magnesium, Fecal Coliform, General/Metals

Air Emissions

SO₂, Percent Oxygen or Carbon Dioxide, Opacity, Particulate Matter, Air Metals^h, Unburned Hydrocarbons, Particle Size Distribution, SO₃/H₂SO₄, NO_x

Sound

dBA, 1/3 Octave Band Spectrum

TABLE 1.2-1 (CONTD)
 PURE AIR, NORTHERN INDIANA
 BAILLY GENERATING STATION ADVANCED FLUE GAS
 DESULFURIZATION PROJECT

ENVIRONMENTAL MEDIA AND PARAMETERS TO BE MONITORED

Major anions: NO₃, SO₄, CO₃

CO, Cd, Cr, Hg, Pb, Se, Ni, Tl, F, Fe, PH, Ti, Mn, Mo, Ba, Sr, V, U

- 9 - The Indiana Neutral Leaching Method Test is the TCLP Test without the addition of acetic acid and includes the analyses for the following: Ba, B, Cl, Cu, Cn, F, Fe, Mn, Ni, Phenols, Na, SO₄, Sulfide as S, TDS, Zn, and pH.
 All metals include the following: As, Cs, Sr, Se, Ba, Cr, Co, Pb, Mn, Ni, Se, Ag, and Zn.

The technical feasibility of performing some of the sampling and analyses, while still generating reliable data, is in doubt for

This may be reflected in revisions to the environmental media

reliable

interface cabinets throughout the AFGU facility that collect

be integrated with the collection of data for the AFGU system.
The existing monitoring system consists primarily of coal

Program Selectees". The information provided in the EMP is based on

This Section 1.0 Introduction, provides information on the purpose and scope of the EMP. A summary has been included of the environmental media and parameters to be monitored and reported to DOE during the 3-year

The next three sections, Section 3.0 Existing Environment, Section 4.0 Consequences (Impacts) of the Project, and Section 5.0 Project Mitigation Measures, contain information from the Environmental Information Volume

discussion in these sections helps provide a basis for developing various aspects of the EMP.

The planned environmental monitoring activities for the AFGD project are presented in Section 6.0 Environmental Monitoring. The categories of

- ° Baseline Studies or Environmental Characterization (Class I Monitoring);
- ° Compliance Monitoring (Class II Monitoring); and
- ° Supplemental Environmental Impact Monitoring (Class III Monitoring).

These three classes of monitoring were specified in the previously mentioned DOE "Environmental Guidance Manual for Innovative Clean Coal

Technology Program Selectees". Subsequent to the issuance of this

(compliance monitoring) and Class II (supplemental monitoring).
Monitoring Classes I and III used in the EMP are equivalent to the two
scheme Class II (supplemental monitoring); whereas, Class II in the EMP

Both Pure Air and Northern Indiana, the project's proponents, will be

Integration of Monitoring Activities, contains information on the

The results of the environmental monitoring will be provided to DOE in
quarterly reports with annual summaries and detailed reports. Section

9.9 Data Management and Reports discusses the data management and

The EMP has been prepared by several project team members. Their names

Professional Qualifications

for air emissions and wastewater discharges. The project is currently

these permits and their monitoring requirements, if any, will be

presented in the EMP.


SECTION 2.0

2.1 PROJECT PROPONENTS, PURPOSE AND LOCATION

The AFGD project will be a cooperative effort between Pure Air and

facility.

significantly reduce SO₂ emissions in an environmentally sound manner at a cost of approximately 50 percent of the cost of currently available Flue Gas Desulfurization (FGD) systems. This emission reduction will be shown to have the potential to be achieved without generating continuous solid or liquid waste disposal problems. The production of a by-product potential for reducing solid waste production. The minimization of liquid waste disposal problems will be demonstrated by a Wastewater



Duneland Beach
Lang Beach

CHICAGO

INDIANA DUNES

Dune Acres

Massville:

Municipal

NATIONAL POLICE SHOW

1000

Road

North

Mass

Green's
Acres
Lumber Co. Highway

Dune Acres

730
Com.
Winfield

Blue River




730
Com.
Winfield



Blue River

a joint venture company
ADVANCED FLUE
GAS RESULFURATION



Location Map



 **Pure Air** 
 a joint venture company
**ADVANCED FLUE
 GAS DESULFURIZATION**

- 1. AIR CONDITIONING
- 2. ELECTRICAL SYSTEM
- 3. FIRE WATER
- 4. SANITARY WATER
- 5. SEWER
- 6. GAS
- 7. POWER

FACE POINTS

- 1. IN
- 2. TO
- 3. TO FUTURE REVISION
- 4. TO
- 5. TO POINT

NOTES

- 1. ALL WORK SHALL BE IN ACCORDANCE WITH THE LATEST EDITIONS OF THE NATIONAL ELECTRICAL CODE AND THE NATIONAL FIRE ALARM CODE.
- 2. ALL WORK SHALL BE IN ACCORDANCE WITH THE LATEST EDITIONS OF THE NATIONAL ELECTRICAL CODE AND THE NATIONAL FIRE ALARM CODE.

FIGURE 2.1-3
 General Arrangement
 Plot Plan

DIMENSIONS
1. 30' x 30'
2. 15' x 15'
3. 12' x 12'
4. 12' x 12'
5. 12' x 12'

NOTES

- 1. BASED ON THE GENERAL ARRANGEMENT DRAWING.
- 2. ALL WORK SHALL BE IN ACCORDANCE WITH THE LATEST EDITIONS OF THE NATIONAL ELECTRICAL CODE AND THE NATIONAL FIRE ALARM CODE.

PERMITS

NO.	DATE	DESCRIPTION
1	10/1/58	ISSUED FOR PERMIT
2	10/1/58	ISSUED FOR PERMIT
3	10/1/58	ISSUED FOR PERMIT

GENERAL LIST

- 1. AIR CONDITIONING
- 2. ELECTRICAL SYSTEM
- 3. FIRE WATER
- 4. SANITARY WATER
- 5. SEWER
- 6. GAS
- 7. POWER

SUMMARY

- 1. IN
- 2. TO
- 3. TO FUTURE REVISION
- 4. TO
- 5. TO POINT

NOTES

- 1. ALL WORK SHALL BE IN ACCORDANCE WITH THE LATEST EDITIONS OF THE NATIONAL ELECTRICAL CODE AND THE NATIONAL FIRE ALARM CODE.
- 2. ALL WORK SHALL BE IN ACCORDANCE WITH THE LATEST EDITIONS OF THE NATIONAL ELECTRICAL CODE AND THE NATIONAL FIRE ALARM CODE.

SEE LIST

SEE LIST

NO.	DESCRIPTION	DATE
1	ISSUED FOR PERMIT	10/1/58
2	ISSUED FOR PERMIT	10/1/58
3	ISSUED FOR PERMIT	10/1/58

STATUS

NO.	DATE	DESCRIPTION
1	10/1/58	ISSUED FOR PERMIT
2	10/1/58	ISSUED FOR PERMIT
3	10/1/58	ISSUED FOR PERMIT

NO.	DATE	DESCRIPTION
1	10/1/58	ISSUED FOR PERMIT
2	10/1/58	ISSUED FOR PERMIT
3	10/1/58	ISSUED FOR PERMIT

- 1. AIR CONDITIONING
- 2. ELECTRICAL SYSTEM
- 3. FIRE WATER
- 4. SANITARY WATER
- 5. SEWER
- 6. GAS
- 7. POWER

FACE POINTS

- 1. IN
- 2. TO
- 3. TO FUTURE REVISION
- 4. TO
- 5. TO POINT

NOTES

- 1. ALL WORK SHALL BE IN ACCORDANCE WITH THE LATEST EDITIONS OF THE NATIONAL ELECTRICAL CODE AND THE NATIONAL FIRE ALARM CODE.
- 2. ALL WORK SHALL BE IN ACCORDANCE WITH THE LATEST EDITIONS OF THE NATIONAL ELECTRICAL CODE AND THE NATIONAL FIRE ALARM CODE.

FIGURE 2.1-3
 General Arrangement
 Plot Plan

DIMENSIONS
1. 30' x 30'
2. 15' x 15'
3. 12' x 12'
4. 12' x 12'
5. 12' x 12'

NOTES

- 1. BASED ON THE GENERAL ARRANGEMENT DRAWING.
- 2. ALL WORK SHALL BE IN ACCORDANCE WITH THE LATEST EDITIONS OF THE NATIONAL ELECTRICAL CODE AND THE NATIONAL FIRE ALARM CODE.

PERMITS

NO.	DATE	DESCRIPTION
1	10/1/58	ISSUED FOR PERMIT
2	10/1/58	ISSUED FOR PERMIT
3	10/1/58	ISSUED FOR PERMIT

- 1. AIR CONDITIONING
- 2. ELECTRICAL SYSTEM
- 3. FIRE WATER
- 4. SANITARY WATER
- 5. SEWER
- 6. GAS
- 7. POWER

SUMMARY

- 1. IN
- 2. TO
- 3. TO FUTURE REVISION
- 4. TO
- 5. TO POINT

NOTES

- 1. ALL WORK SHALL BE IN ACCORDANCE WITH THE LATEST EDITIONS OF THE NATIONAL ELECTRICAL CODE AND THE NATIONAL FIRE ALARM CODE.
- 2. ALL WORK SHALL BE IN ACCORDANCE WITH THE LATEST EDITIONS OF THE NATIONAL ELECTRICAL CODE AND THE NATIONAL FIRE ALARM CODE.

SEE LIST

SEE LIST

NO.	DESCRIPTION	DATE
1	ISSUED FOR PERMIT	10/1/58
2	ISSUED FOR PERMIT	10/1/58
3	ISSUED FOR PERMIT	10/1/58

STATUS

NO.	DATE	DESCRIPTION
1	10/1/58	ISSUED FOR PERMIT
2	10/1/58	ISSUED FOR PERMIT
3	10/1/58	ISSUED FOR PERMIT

NO.	DATE	DESCRIPTION
1	10/1/58	ISSUED FOR PERMIT
2	10/1/58	ISSUED FOR PERMIT
3	10/1/58	ISSUED FOR PERMIT

2.2 PROJECT PHASES

will comprise the demonstration period of the project; whereas, the

focus primarily on environmental baseline or characterization monitoring

monitoring data that will be provided to DOE will be collected during the 3-year demonstration phase of the project.

2.3 PROJECT SCHEDULE

A preliminary overall project schedule is as follows:

1. Last quarter 1988 through third quarter 1992 - Phase 1 Design and Permitting: Includes development of Environmental Information Volume (EIV) and Environmental Assessment (EA), developing design data, process engineering, detail engineering, equipment procurement, obtaining all engineering and environmental permits and development of the EMPD and EMP.
2. Second quarter 1990 through second quarter 1992 - Phase 2 Construction and Start-up: Includes providing construction utilities, modifying existing Dolly Station facilities.
3. Third quarter 1992 through third quarter 1995 - Phase 3 Demonstration Operation: Includes providing utilities for monitoring, engineering, and environmental management reporting results of operation to the DOE.
4. Third quarter 1995 through 2012 - Phase 4 Commercial Operation: Includes compliance monitoring and commercial operation arrangement between Pure Air and Northern Indiana.

2.4 PROCESS DESCRIPTION


involves using Mitsubishi Heavy Industry's (MHI) basic wet limestone FGD technology on high sulfur United States coals to achieve high SO₂

exits through the stack;

- Gypsum By-Product Handling System where the gypsum slurry is reduced to dewatered cake containing 8 to 10 percent moisture by weight. Filtrate water is returned to the Absorber System, and a wastewater

join the main flue gas stream. Dry solids are removed by the ESP.

AS DUSTING AND
NS SECTION



EXHAUSTION

EXHAUSTION

WATER



WATER

WATER

WATER



REMOVAL SEC




WATER

WATER

WATER


WATER



WATER

WATER

WATER



WATER

WATER

Pure Air
a joint venture company
ADVANCED FLUE
GAS DESULFURIZATION

Process Flow Schematic

Figure 2.4-1

2.5 EMISSIONS AND DISCHARGES

wastes generated during both construction and operation. These emissions

discussed in Section 6.2 Compliance Monitoring (Class II Monitoring) in relation to existing Bailly Station permit limits.

2.5.1 ATMOSPHERIC EMISSIONS

fugitive dust. Operational emissions of SO₂ will be reduced based on the AFGD system's expected performance. NO and

2.5.2 WASTEWATER DISCHARGES

Wastewater generated during construction will consist primarily of stormwater runoff. During operation a portion of the process

process and then eliminated. Any remaining process liquid wastes from the AFGD system and domestic wastes will be discharged to wastewater treatment systems.

not sold or off-specification, (3) normal construction waste materials, (4) solids from the wastewater treatment system, and

manufacturer requirements.

Gypsum Composition

<u>Parameter</u>	<u>Weight Percent (Dry Basis)</u>
CaSO ₄ · 2H ₂ O	93.0 min (95.0 expected)
CaSO ₃ · 1/2 H ₂ O	2.0 max
SiO ₂	2.5 max
Fe ₂ O ₃	1.5 max
R ₂ O ₃ (other metal oxides)	3.5 max
pH (units)	5 to 8
Free H ₂ O (percent)	10 max

The other metal oxides in the gypsum are expected to consist primarily of oxides of magnesium, sodium, and potassium.

2.6 EMISSIONS AND DISCHARGES CONTROL

The AFGD system will be constructed and operated in compliance with all

and solid waste disposal as described below.

2.6.1 ATMOSPHERIC EMISSIONS CONTROL

During construction fugitive dust will be controlled by good

truck traffic will be controlled by utilizing covered trucks and a weekly paved roadway water flushing program.

Operation of the AFGD system will control SO₂ emissions. NO_x and particulate emissions will be essentially the same as those currently emitted by the Bailly Station.

Department of Environmental Management (DEM), Office of Air Management (OAM). Information on the Construction Permit is included in Section 6 Environmental Monitoring. The Operating

and will be applied for approximately 60 days before AFGD system start-up.

2.6.2 WASTEWATER DISCHARGES CONTROL

Surface storm runoff from precipitation events will be controlled using runoff channels, straw bales or other suitable methods. The

water. The domestic sewage or sanitary wastes will consist of

sewage treatment facility.

Process related wastewater will consist of a filtrate wastewater

in operation this wastewater will be directed to a wastewater

the bleed stream will be routed to the WES with the remainder sent to the wastewater treatment system.

The discharge of wastewater from the AFGD system will be in compliance with a modification to the Bailly Station's National

the 10th, Office of Water Management (OWM) as discussed in section

Solid wastes generated during both construction and operation of

(e.g., wallboard) as previously indicated. Gypsum not sold, including off-specification gypsum, will be landfilled.

The disposal of solid wastes will be done in compliance with

Environmental Monitoring.

SECTION 3.0

EXISTING ENVIRONMENT

environment was described in the vicinity of the Bailly Generating Station.

Land Resources Water Resources Ecological Resources Socioeconomic

3.1 ATMOSPHERIC RESOURCES

3.1.1 SITE METEOROLOGY

cold, dry winters and warm, moist summers. These climatic characteristics are the result of storms moving eastward along the northern tier of the United States and storms in the southwest moving toward the Great Lakes. The average temperature for the area is approximately 50°F, with the highest temperatures occurring between the equator and the equator. The lowest temperatures occur in the

Indiana (4 miles southwest of the Station) are -21°F and 104°F (Gale Research Company, 1985).

As indicated above, the area is known for frequent high winds,

1° longitude sector containing the plant site. Using the Thom (1962) technique, the angle for a tornado striking a point in this

At the Indiana at the Penn State substation (2 miles southwest of

the Bailly Station) are shown in Figure 3.1-1 and indicate that the


There are important climatological differences between dune areas, which include the plant site, and more urban inland areas. The

area. The area (Porter County) is presently classified as

pollutants (SO₂, NO₂, CO and Pb) are in attainment. It is of

Recently, IDEM conducted a study to develop a control strategy to attain the National Ambient Air Quality Standards (NAAQS) for SO₂. The result of this study indicated that the NAAQS for SO₂ are being met, however, the concentrations predicted were very

As indicated above, the area is currently designated as "attainment" or unclassifiable for all criteria pollutants except



1-3 4-6 7-10 11-16 $\left\{ \begin{array}{l} \text{---} 17-21 \\ \text{---} > 21 \end{array} \right.$

[Redacted] [Redacted]

Note:

Wind direction is the direction from which the wind is blowing.

GAS DESULFURIZATION

Wind roses for 1994-1996

Figure 3.1-1

1/91

Northern Indiana has collected air-quality data at the Bailly

SO₂ monitoring sites. Northern Indiana does not currently

exceed 40 percent.

emissions estimated at 627 tons and 60,976 tons, respectively. For the period August, 1988 through August, 1989, the Station's average

3.2 LAND RESOURCES

3.2.1 GEOLOGY

TABLE 3.1-1

PURE AIR, NORTHERN INDIANA
 BAILLY GENERATING STATION ADVANCED FLUE GAS
 DESULFURIZATION PROJECT

1988 MONITORING DATA FOR PM₁₀, SO₂,
 AND NO_x NEAR BAILLY GENERATING STATION

24-Hr	Duneland		75	150
Annual ^b	Steel		32	50
SO ₂				
3-Hr	Dune Acres	1.4 mi SE	430 ^a	1,300

NO_x

III.

Footnotes:

- a - Second highest concentration.
- b - Geometric mean.
- c - Arithmetic mean.

Source:

Ritter, K. September 13, 1989. Indiana Department of
 Environmental Management, Indianapolis, Indiana. Monitoring
 data report sent to M. Mitckes, EBASCO, Oak Ridge, Tennessee.

The geology at the southern shore of Lake Michigan represents a complex history of glacial, shallow-water coastal, lake, wetland, and beach/dune sedimentation that began during and after the final

approximately 4,000 ft thick. The thickness of this lowermost

The middle unit consists of an assemblage of interbedded till, glacial/lake clay, sand, and gravel. This unit crops out in the region as the Lake Border Moraine (Figure 3.2-1). The glacial/lake deposits are well developed northward within this unit where it extends under Lake Michigan and the till deposits of the middle

exposed on the surface of the Lake Border Moraine, whereas the core consists of till interbedded sand and gravel.

form the Glenwood, Calumet and Tolleston Beaches, and interridge marshes. This series of the beach/dune complexes began forming between 14,500 and 12,400 years ago in response to rises and falls

NORTH SOUTH




Figure 3.2-1. Cross-section perpendicular to the Lake Michigan shoreline showing geology and groundwater movement near the Bailly Generating Station.

Source: D. A. Cohen, 1980; Thompson, 1987


Pure Air

 ADVANCED FLUE

3.2.2 SEISMOLOGY

The Bailly Station is located in an area of minor seismic activity have been reported for epicenters within 100 miles of the Station.

Soils located in the vicinity of the station are composed primarily of five types: Oakville fine sand, Houghton muck, Adrian muck, Maumee loamy fine sand, and Dune land. The large portion of ground used for industrial purposes in the area is classified as cut and fill. This is illustrated in Figure 3.2-2, "Soil Composition - Bailly Generating Station Area."

Soils in the subdunal area and interdunal ponds are composed of muck surface layer. The very poorly drained organic material of

The soils of the subdunal area and interdunal ponds are composed

TABLE 3.2-1

PURE AIR, NORTHERN INDIANA
BAILLY GENERATING STATION ADVANCED FLUE GAS
DESULFURIZATION PROJECT

MODIFIED MERCALLI SCALE

- I. Not felt except by a few under especially favorable circumstances.
- II. Felt only by a few persons at most, especially on upper floors of buildings.
- III. Felt quite noticeably indoors, especially on upper floors of buildings, but many people do not recognize it as an earthquake. Standing automobiles may rock slightly. Vibration like passing of truck. Duration estimated.
- IV. During the day felt indoors by many, outdoors by few. At night sometimes wakes sleepers.
- V. Felt by nearly everyone, many awakened. Some dishes, windows, etc., broken; a few instances of cracked plaster; unstable objects overturned. Disturbance of trees, poles, and other tall objects.
- VI. Everybody runs outdoors. Damage negligible in buildings of good construction and in specially designed structures; considerable in poorly built or badly designed structures; some chimneys broken. Noticed by persons driving cars.
- VII. Everybody runs outdoors. Damage negligible in buildings of good construction and in specially designed structures; considerable in poorly built or badly designed structures; some chimneys broken. Noticed by persons driving cars.

TABLE 3.2-1 (CONTD)

PURE AIR, NORTHERN INDIANA
BAILLY GENERATING STATION ADVANCED FLUE GAS
DESULFURIZATION PROJECT

MODIFIED MERCALLI SCALE

VIII. Damage slight in specially designed structures; considerable in

structures. Fall of chimneys, factory stacks, columns, monuments,

IX. Damage considerable in specially designed structures; well-designed
frame structures thrown out of plum; great in substantial

X. Some well-built wooden structures destroyed; many masonry and frame
structures destroyed with foundations; ground badly cracked. Rails
bent. Landslides considerable from river banks and steep slopes.
Shifted sand and mud. Water splashed (sloped) over banks.

XI. Few, if any, (masonry) structures remain standing. Bridges

ground. Rails bent greatly.

XII. Damage total. Waves seen on ground surfaces. Lines of sight and
level distorted. Objects thrown upward into the air.

Ad	Adrian Muck	MIA	Martinsville Loam, 0-2% Slopes	Oaf	Oakville Fine Sand, 12-25% Slopes
BoA	Blount Silt Loam, 0-3% Slopes	Ma	Maumee Loamy Fine Sand	Oaf	Oakville Fine Sand, 25-65% Slopes

LAKE MICHIGAN

BAILLY STATION

GREENBELT

COWLES BOG NATIONAL NATURAL LANDMARK

0' 400' 800' 1200' 1600' 2000'
GRAPHIC SCALE

CHICAGO SOUTH

PIE 12

GAS DESULFURIZATION

Figure 3.2-2

1/91

Soils at the southern end of the subdunal area are composed of

Dune sand occupies the area extending inland from the shore of Lake

species.

3.2.4 LAND USE

The station is bordered on the south and west by the Bethlehem Steel Corporation's Burns Harbor complex. The Indiana Dunes National Lakeshore borders the site to the east and the south.

Chicago, all of which are centers of heavy industry. Steel manufacturing is the major industry site Gary,

Very little of the land north of U.S. Route 12 is either suitable

station.

3.3 WATER RESOURCES

3.3.1 GROUNDWATER

There are three major aquifers (basal, subfill and surficial)

Generating Station (Figure 3.2-1). The lowermost basal sand

The sandstone is overlain by a thin layer of clay. The subfill aquifer is part of Thompson's (1987) middle unit and extends into the low-lying area of the Lake Superior (the interdunal wetland between the Calumet and Tolleston Beaches)

Generating Station is the surficial aquifer which consists of lake, beach and dune sand deposits. The surficial aquifer is developed in all areas adjacent to the Station, except where glacial moraines are exposed at the surface. In the vicinity of the Barry Generating Station, the surficial aquifer is over 50 ft thick.

Groundwater flow in the region may be divided into regional,

deposits upon the Moraine into the upper bedrock and then

leakage into drainage systems in the Great Marsh.

Local flow systems within the surficial aquifer are recharged in the dunebeach complexes and discharge into streams, ditches, and ponds in the interdunal wetlands. The shallow groundwater flow

beach complexes. Shallow groundwater flows northward and southward from these divides and discharges into adjacent low-lying areas and wetlands. The Bailly Generating Station is located to the west of the river valley and underlying the shoreline sand-beach complex (Figure 3.2-1). The shallow groundwater flows directly into Lake

From 1967 to 1980, fly-ash produced during operation of the Bailly Generating Station was collected by ESPs and transported as a slurry to a series of unlined settling ponds located on the

evaluation of monitoring wells in the area, Meyer and Tucci (1979) determined that seepage from these ponds, estimated at 2 million

In late 1979, the Station discontinued use of the easternmost

by lining with a 1 ft thick layer of clay and a 0.12 inch thick

arsenic, and strontium) relative to background levels outside the

some concentrations showed no discernible trends, and remained above background levels. Cohen and Chedoke (1986) suggested that the

(confined aquifers) beneath the Station.

within 1-mile of the station, and a total of three wells at a distance of 2 miles. The nearest municipal water system is that of depth of about 30 ft, approximately 300 ft from the shoreline of

found in groundwater throughout the Bailly Station area. This indicates that a portion of the groundwater originates from the percolation of rain and surface water through the sandy soils of the dune forests and through the bogs and peaty areas in the region.

3.3.2 SURFACE WATER

There are a number of springs, streams, rivers, and bogs in the general area of the Station. However, there are no water-

the Indiana Dunes National Lakeshore. Some marshy areas to the east and south of the Bailly Station empty into Lake Michigan via

Burns Ditch to the west of the Station is one ditch of an extensive system of ditches that were constructed to facilitate drainage.

introduced into the lake use Burns Ditch for access to their spawning grounds in the Little Calumet River.

lowest in late winter and early spring. The lake is divided into two basins by two parallel ridges running in an easterly direction

the shore of the southern basin.

The Lake Michigan beach water zone is the portion of water that extends from shore to a depth of 30 feet. It is a subarea of the inshore zone that comprises 7 percent of the lake surface.

Over a 5-year study (March, 1974 to December, 1978), lake temperatures ranged from 37.4° to 73.4°F. Ice may cover the

Ice melting and warming of lake waters seasonally occurs the latter

Lake Michigan has two circulation periods each year, with overturns occurring early winter and early spring in the southern basin.

During each approximately month long period, vertical mixing is almost complete and the lake approaches an isothermal temperature

phytoplankton growth. Water movements are also influenced by

somewhat.

velocities in the upper layer measured at the Station were 40 cm/s. Seiches occur occasionally at the southern end of the lake.

Bailey Generating Station and associated AFGD System are above the

100-year flood elevation.

Freshwater habitats include drainage streams, ponds, bogs, springs and

of mammals reside on the site of the proposed fire system or on the
Bailly Station. In addition, the current habitats or migratory patterns
of wildlife will not be disturbed in any way by the proposed construction
of the AFGD System.

3.4.1 TERRESTRIAL

(former farmland) and associated forest components further inland.
Each of these areas has its particular floral composition and

TABLE 3.3-1

PURE AIR, NORTHERN INDIANA
BAILLY GENERATING STATION ADVANCED FLUE GAS
DESULFURIZATION PROJECT

LAKE MICHIGAN FLOOD ELEVATIONS
(NATIONAL GEODETIC VERTICAL DATUM - 1929)

<u>10-Year</u>	<u>50-Year</u>	<u>100-Year</u>	<u>500-Year</u>
583.0	583.9	584.2	584.8

Source:

Federal Emergency Management Agency, 1991.

faunal components, although larger animals can be expected to move freely from place to place. The Cowles and Pinhook Bogs, within the National Lakeshore Boundaries, are two intensively studied bogs; they are typical of other bogs and wetlands within the

principally by insects that feed on carrion (fish and birds) cast up on the shoreline. These insects in turn are preyed upon by shore birds and other insects. Plant life per se is essentially

The area in the Bailly Station where the AFGD system will be constructed contains only a small amount of vegetation on the north-facing slope. Some of this area will be filled during

species.

3.4.1.1 Vegetation

In the vicinity of the Bailly Station the mid-beach supports a few hardy pioneer plant species (i.e., coarse plants such as the cocklebur and sea rocket). Immediately adjacent to this

these plants and other grasses are typical of a beach succession ecosystem. In some areas successful changes may be observed in the recovery of the former development of such an ecosystem.

The dune line (foredune) has both active and temporarily

more stable foredunes are shrubs, such as cherry and little

forest stands of small black oak, jack pine, large tooth

and bittersweet predominate and are interspersed with

trees. On active dunes, the north-facing slopes are covered with bearberry, common junipers, cottonwood, and willow which provide good vertical and horizontal wind shielding.

Forest communities are adjacent to the dunes. The canopy trees are almost all black oak, although basswood is occasionally present. Oak seedlings, wild cherry, sassafras, and witch hazel comprise the understory. The oak forest is classified as both immature and mature. The vegetation

has older oaks and a more spotty distribution of herbaceous plants and woody shrubs. Shade-tolerant forms such as bracken fern live under the oaks. There are open areas of sand which are stabilized by sedges and little bluestem grasses. In general, as one goes inland the soils become increasingly clayey (loess drift deposits) so that they have higher water and nutrient retention than the dunes. The forests provide diverse microhabitats in the rotting logs, fallen leaves and branches of the forest litter.

The National Lakeshore has a native stand of predominantly

oaks are occasionally found in this forest habitat with some

12 additional tree species. Most of the saplings are

Old field habitats exist within the boundaries of the National Lakeshore and ponds are common in the sand dunes. Old field vegetational types are characteristically mosses, sedges and grasses, cattails and herbs, and maple, cherry and oak seedlings.

masses of sphagnum moss surrounding areas of open water. Other

3.4.1.2 Vertebrates

Vertebrates in the Bailly Generating Station area include

woodchuck. Scats (animal feces) or footprints of deer, raccoon, and fox also have been observed in the area.

Lower vertebrates encountered in the Station area include the red backed salamander, green frog, wood frog, eastern snake

summer residents, six are winter residents, and 26 are

Lakeshore; however, it has been established that the species

Within the vicinity of the Bailly Station are flyways (migration corridors) of several types of migratory waterfowl, including the "dabbling ducks" (e.g., mallard, black duct and pintail), the "diving ducks" (e.g., redhead

the

near shore waters of the lake and in the interannual ponds near the lake.

human habitation and the encroachment of industry along the Lake Michigan shoreline of the Chicago-Hammond-Gary area, the

zooplankton, and phytoplankton as described below.

TABLE 3.4-1

PURE AIR, NORTHERN INDIANA
 BAILLY GENERATING STATION ADVANCED FLUE GAS
 DESULFURIZATION PROJECT

ABUNDANT BIRD SPECIES KNOWN TO NEST
 IN THE INDIANA DUNES AREA

Common Name

Common Name

Red-Billed Gull

Mallard

Red-Eyed Vireo

Sora
 Common Gallinule
 American Coot
 Killdeer
 American Woodcock

Ovenbird
 Common Yellowthroat
 American Redstart
 House Sparrow
 Bobolink

Yellow-Billed Cuckoo

Brown-headed Cowbird

Downy Woodpecker

American Goldfinch

Eastern Kingbird
 Eastern Wood Peewee
 Horned Lark
 Tree Swallow
 Bank Swallow
 Barn Swallow

Song Sparrow
 Tufted Titmouse
 House Wren
 Marsh Wren
 Gray Catbird

3.4.2.1 Fish

Fourteen fish species in seven families have been verified in Lake Michigan and several ponds near the

and salmonids comprised the third largest number of

rare or endangered fish species in the aquatic community (Lake Michigan, rivers, bogs, marshes, streams, ponds) in the Bailly Station vicinity. Table 3.4-2 lists the fish species identified in the area.

The Bailly Station's thermal plume in Lake Michigan

yellow perch, bluegill, and large mouth bass. Several species of minnows and two species of suckers also have been found in the area. These fish are important as forage for the game species, but are not sought after for sport or food. Five species of importance for sport or food, especially in the spring, are coho salmon, lake trout, steelhead trout, chinook salmon, and alewives. Other fish of marginal importance, such as carp, bullhead, and goldfish, may also appear near the Station.

Three fish species have been found in ponds in the Bailly Station vicinity. These are the most abundant species.

TABLE 3.4-2

PURE AIR, NORTHERN INDIANA
 BAILLY GENERATING STATION ADVANCED FLUE GAS
 DESULFURIZATION PROJECT

FISH SPECIES VERIFIED IN THE AQUATIC COMMUNITY

<u>SCIENTIFIC Name</u>	<u>Common Name</u>
Family Clupeidae	Herring Family
Dorosoma cepedianum	Gizzard Shad
Alosa pseudoharengus	Alewife
Family Salmonidae	Salmon, Trout and Whitefish Family
Oncorhynchus tshawytscha	Chinook Salmon
Oncorhynchus kisutch	Coho (Silver) Salmon
Salmo trutta	Brown Trout
Family Umbridae	Mudminnow Family
Umbra limi	Central Mudminnow
Family Cyprinidae	Minnow Family
Cyprinus carpio	(European) Carp
Notropis hudsonius	Spottail Shiner
Family Centrarchidae	Sunfish Family
Leponis cyanellus	Green Sunfish
Family Percidae	Perch Family

3.4.2.2 Benthic Macroinvertebrates

The hard sand bottom and seasonal water temperatures along

bottom sediments and have been estimated to comprise slightly more than half of the total benthic organisms present. Some species are highly pollution tolerant.

Most of the other species of benthic organisms are of a type characteristic of conditions elsewhere in the lake and include leeches, fingernail clams, scuds, and midge larvae.

Crayfish have been observed in the Station.

Table 3.4-3 identifies the macroscopic animals native to the park and the lake. The benthic macroinvertebrate community that surround the Bailly Station site.

3.4.2.3 Zooplankton

Zooplankton, by nature of their feeding,

noted that during this study, zooplankton samples were

TABLE 3.4-3

BAILY GENERATING STATION ADVANCED FLUE GAS

Family Name	Common Name
Libellulidae	Dragonflies
Coenagrionidae	Damselflies
Corixidae	Water Boatmen
Nepidae	Water Scorpions
Gerridae	Water Striders
Mesoveliidae	Water Treaders
Lymnaeidae	Pond Snails
Aeschnidae	Dragonflies
Notonectidae	Backswimmers
Hebridae	Velvet Water Bugs
Gyrinidae	Whirligig Beetles
Hydrophilidae	Water Scavenger Beetles
Chrysomelidae	Leaf Beetles
Gammaridae	Scuds
Hydracarina	Water Mites
Physidae	Pouch Snails
Hirudinea	Leeches
Chironomidae	Midges
Veliidae	Smaller Water Striders
Dytiscidae	Predaceous Diving Beetles
Planorbidae	Orb Snails
Sphaeriidae	Fingernail Clams
Halplidae	Crawling Water Beetles
Artacidae	Cray Fish
Asellidae	Scud Bugs
Elmidae	Riffle Beetles
Naucoridae	Creeping Water Bugs

Source: Krekeler, C.H., et al. 1981. Exosystem Study of the Indiana Dunes National Lakeshore, Vols. One and Two.

collected on one day only). Of these, Bosmina longirostris and copepod copepodids were the most abundant

occurring regularly included Cyclops bicuspidatus thomasi, Daphnia retrocurva (lake stations), and Chironomidae larvae (pond stations). Numerical density ranges from 0.44 to 117.79 organisms/liter in the lake and 50.00 to 964.74 organisms/liter in the sampled ponds, an indication of the higher productivity in the ponds. Spatial and temporal statistical differences were detected between groups of zooplankton stations and reflect the changing

quantitative distribution indicates that these microcrustaceans were over three times more abundant

suggest that certain species of zooplankton are either seeking out the warmer water of the plume, reproducing

the two factors.

A large portion of the zooplankton found in the thermal plume had large infestations of fungus on their bodies. This was especially apparent in Eurytemora affinis and Daphnia retrocurva, the most abundant organisms in the

plume did not exhibit any infestations of fungus.

sometimes occurs in polluted areas such as in southern Green Bay.

3.4.2.4 Phytoplankton

Phytoplankton populations in Lake Michigan reflect seasonal changes in available light, temperature, nutrients and predation. Diatoms dominate the lake flora from mid fall through early spring. Blue-green algae become briefly dominant in late spring, and green algae

Productivity levels in the lake are very low, particularly as compared to nearby river systems. Productivity levels in the ponds are somewhat higher but still within a low range. A relationship between productivity, biovolume and density of the phytoplankton is

phytoplankton population.

Peridinium sp. are the more abundant dinoflagellates. These forms have been previously reported from Lake Michigan but not in these concentrations. These organisms are especially abundant in the warm water discharge from the Bailly Station.

Blue-green algae (Cyanophyta) are also abundant in the warm water. The major species in this population is Gomphosphaeria lacustris.

Other golden-brown algae and green algae are present in smaller concentrations. Dinobryon sp. is commonly found throughout Lake Michigan. The green algae Scenedesmus

but is found in highest volumes in Burns Ditch. With

that water and related materials from Burns Ditch are drifting eastward into the vicinity of Bailly Station discharge plume.

are found in the lake in normal and unpolluted situations. Cladophora glomerata and Lyngbya dignetti,

the first and second most common forms encountered near the Bailly Station. Although Cladophora is normally observed in shoreline habitats of Lake Michigan, it should be noted that its growth is responsive to temperature and nutrient concentration. Under conditions of accelerated growth this species has become a nuisance since it can slough off of its substrate, wash ashore, and decompose, producing foul odors. The attached algae harbors several

3.5 SOCIOECONOMIC RESOURCES

3.5.1 POPULATION

Northern Indian property. Portage is the largest city in the 5-mile vicinity, with a population in 1980 of 27,409.

TABLE 3.5-1

PURE AIR, NORTHERN INDIANA

POPULATION DATA FOR INCORPORATED COMMUNITIES

<u>Community</u>	<u>Miles/Direction From Site</u>	<u>Census</u>		<u>% Change</u>
		<u>1970</u>	<u>1980</u>	
Dune Acres	2.0 ENE	301	291	-3.3

Sources: U.S. Department of Commerce, Bureau of the

Northwestern Indiana Regional Planning Commission.
1987. County Profile: Porter County.

1988. The available labor force in 1987 was 33,500.

estimate can be made of the unemployment rate within the Bailly Station vicinity.

3.3.2 LAND USE

3.5.2.1 Regional

The Bethlehem Steel Corporation, Burns Harbor complex borders the site on the west and south perimeter. The

Within 2 miles of the Bailly Station there is very little permanent residential population because of the wide use of the land for purposes other than housing. A windshield survey of the Lakeshore area (January 1989) revealed a moderate amount of residential construction underway.

Station, however, almost no new homes or condominiums were observed under construction.

3.5.2.2 Industrial

zones of land. The Station's land use is related to

equipment, a coal storage area and associated facilities, wastewater ponds and treatment facilities, and parking.

which serves as a buffer between the Station and the National Lakeshore.

The area around the site, and in particular the area to

Chicago, all of which are centers of heavy industry, particularly the steel manufacturing industry. Besides the steel industry, construction companies and firms producing fabricated metal products as well as petroleum

3.5.2.3 Agricultural

Very little of the land north of U.S. Route 12 is either suitable or used for agriculture. To the south of the Indiana Toll Road, the land in Porter, Lake and LaPorte

TABLE 3.5-2

PURE AIR, NORTHERN INDIANA
 BAILLY GENERATING STATION ADVANCED ELUE GAS

MAJOR MANUFACTURING ACTIVITY WITHIN A 5-MILE
 RADIUS OF THE BAILLY GENERATING STATION ^a

<u>City</u>	<u>Miles/Direction From Site</u>	<u>Industry</u>	<u>Product</u>	<u>No. of Employees</u>
Chesterton	1/SE	Bethlehem Steel (Burns Harbor)	Steel mill	6,200
Chesterton	4.5/SE	Luria Brothers	Scrap metal processing	122
Chesterton	4.5/SE	Manley Brothers	Stone, clay, glass products	125
Portage	4.5/SSW	Bethlehem Steel	Steel mill	6,000
Portage	4.5/SSW	The Levy Co.	Stone, clay, glass products	300
Portage	4.5/SSW	National Steel	Steel Mill	1,700

Footnote: ^a - Major manufacturers include those industries with 100 or more employees.

3.5.3 PUBLIC SERVICES

3.5.3.1 Schools, Hospitals and Nursing Homes

Table 3.5-3 lists the six hospitals within a 12-mile

special education, elementary, junior high, and high schools are covered by these data. Day care centers and pre-school facilities are not required to be monitored by the Indiana Department of Education, so no enrollment or location information is available.

Table 3.5-5 indicates the nursing homes and number of beds in the station area.

The Bailly Station is located in an area where access to transportation facilities is readily available. The two-lane U.S. Route 12 borders the Station boundary on the south as does the Chicago South Shore & South Bend Railroad (CSS&SB). A six-lane segment of an interstate highway, I-94, is located about 4 miles south of the

Station is located on the edge of Lake Michigan, it is possible to reach it by way of the lake. Figure 3.5-1 indicates the various routes of transportation to the station. Northern Indiana has a relatively high density

TABLE 3.5-3

PURE AIR, NORTHERN INDIANA
 BAILLY GENERATING STATION ADVANCED FLUE GAS
 DESULFURIZATION PROJECT

Hospital	Location	No. of Beds
St. Mary Medical Center	Hobart	300
St. Anthony	Michigan City	190

Caution with Lead & Radium, Environmental, West Orange, No.

TABLE 3.5-4

PURE AIR, NORTHERN INDIANA
 BAILLY GENERATING STATION ADVANCED FLUE GAS
 DESULFURIZATION PROJECT

PUBLIC SCHOOL ENROLLMENT FOR COMMUNITIES WITHIN A 12-MILE
 RADIUS OF THE BAILLY GENERATING STATION

<u>Community</u>	<u>No. of Schools</u>	<u>1988 Pupil Enrollment</u>
Porter	1	353
Portage	9	8,059
Hebron	3	1,425
Valparaiso	19	8,737

TABLE 3.5-5



PURE AIR, NORTHERN INDIANA
 BAILLY GENERATING STATION ADVANCED FLUE GAS
 DESULFURIZATION PROJECT

NURSING HOMES AND BED TOTALS WITHIN A 12-MILE
 RADIUS OF THE BAILLY GENERATING STATION

Community	No. of Nursing Homes	Total Beds
Chesterton	[REDACTED]	100
[REDACTED]		
[REDACTED]		

5-Mile Radius

LAKE MICHIGAN



4. Dura Air

510 REGULATORY ACTION

of railroad mainlines and principal highways that feed

in 1988 include Conrail and CSX. Direct commuter passenger service to the station entrance is available via the CSX commuter rail service.

Several principal highways pass within 10 miles of the Station, including Interstate Highways 80, 90 and 94, 20, 12 and 6, all of which run north-south through Gary. U.S.

Route 12 runs north-south through Gary, Indiana, and connects directly to U.S. Route 12. At present U.S. Route 12

(NPS) is in progress to determine the feasibility of

truck traffic along the highway by the Bailly-Bethlehem Steel sites. Results of the study are expected sometime in 1991.

There are no state-supported historical sites in Porter County. On the federal level, the Joseph Bailly Homestead and Cemetery are located within 2 miles of the Bailly Generating Station. The Bailly Homestead is listed in the National Register of Historic Places.

The South Shore Station at Beverly Shores has been nominated to the National Register of Historic Places as the only surviving example of stations from the early period of South Shore history. Northern Indiana owns the property on which the South Shore Station sits; it is

approximately 10 miles from the Bailly Station. The National Park Service has approved the application; the state is currently reviewing it and if the site meets state criteria, it will be submitted to and reviewed by the National Director of Historic Sites.

There are no known significant deposits or archaeological remains within the Bailly Station boundary. Within a few miles of the site. Cowles Bog, the closest, lies immediately to the east of the Station boundary. Dunes Nature Preserve is located within the Indiana Dunes State Park between the towns of Dune Acres and Beverly Shores. Pinhook Bog is situated about 12 miles east of the Station.

3.5.3.4 Recreation

Except for the 2 miles of industrial lakefront occupied by

Port of Indiana, most of the 15 miles of lakeshore in

water is generally shallow within 50 ft of the shore line

that line the shore of Burns Ditch and the public harbor at Michigan City.

lakeshore, bogs and marshes. Public Law 89-761, passed

sufficient lands had been acquired to be administered

effectively as a unit. The Lakeshore was formally established in 1972 and is now administered by the National Park Service.

Fishing in Lake Michigan is a popular recreational pastime. Anglers fish from boats anchored near the end of the Bailly Station circulating water discharge plume where salmon, trout and perch are frequently in abundance. The [redacted] prevent anglers from continuing to use this excellent fishing spot.

Inland fishing is very limited. The inland lakes are not stocked by the Department of Natural Resources so local

vaiparaiso area.

Northern Indiana currently operates two electric generating units at the Bailly Generating Station. The units are coal fired and rated at 528 MW

the site, whereas the natural gas is delivered by an underground pipeline

at an average of 221 million gallons per day (MGD).

Every 2 to 3 years the Station must dredge the area surrounding the

at area beaches.

3.7 REFERENCES

and Steel Plants, Pittsburgh, PA

Oak Ridge National Laboratory, Oak Ridge, TN.


communication with Laura Kowalsky, Enviroplan, West Orange, NJ.

Public Health Statistics. Indianapolis, Indiana. Personal communication with Laura Kowalsky, Enviroplan, West Orange, NJ.

Federal Emergency Management Agency. 1981. Flood Insurance Study,



Indiana



Maps: C
Communit
Harbor,
0001B ar

Program 81-01. National Park Service, Midwest Region.

Lane, K. January 9, 1989. Indiana Department of Education,
Educational Information Systems, Indianapolis, Indiana. Written
communication with Laura Kowalsky, Enviroplan, West Orange, NJ.

Martin, M. L. January 20, 1989. Indiana Natural Heritage Program.

Laura Kowalsky, Enviroplan, West Orange, NJ.

Morgan, M. T. September 15, 1980. Northern Indiana Public Service
Company, Hammond, Indiana. Written communication to Lance Roberts,
Oak Ridge, National Laboratory, Oak Ridge, TN.

Northern Indiana Public Service Company. 1973. Bailly Generating
Construction.

Northern Indiana Public Service Company. 1974-1981. Annual Report
- Bailly Nuclear-1 Site. Prepared by Texas Instruments Inc.,
Ecological Services. Dallas, TX.

Northern Indiana Public Service Company. 1981. Bailly Generating
Station Nuclear 1. Environmental Report.

Indian@97 Report4

Laura Kowalsky, Enviroplan, West Orange, NJ.

Health Facilities Division. Indianapolis, Indiana. Personal
communication with Laura Kowalsky, Enviroplan, West Orange, NJ.

Rand McNally Company. 1985. Rand McNally Handy Railroad Atlas.

1986. Population Projections 1990 - 2020. County Profiles

Planning Commission, Census and Statistical Data Center, Highland,
Indiana. Written communication to Laura Kowalsky, Enviroplan, West
Orange, NJ.

Ritter, K. September 6, 1989. Indiana Department of Environmental Manage-
ment. Environmental Management System. Environmental Management System
TN.

Ritter, K. September 13, 1989. Indiana Department of Environ-

Thom, H.C.S. 1963. Tornado Probabilities. Monthly Weather Review
91:730-736.

Thompson, T.A. 1987. Sedimentology, Internal Architecture and
Depositional History of the Indiana Dunes National Lakeshore and
State Park. Ph.D dissertation. Indiana University. Bloomington
unpublished.

U.S. Department of Commerce, Bureau of Census. 1982. U. S. Census
of Population: 1980 - Number of Inhabitants, Indiana. Washington,

SECTION 4.0

Impacts during construction and operation of the ARGD system as discussed in

4.1 ATMOSPHERIC RESOURCES IMPACTS

4.1.1 Construction

These impacts will be primarily associated with vehicle emissions and fugitive emissions or dust. However, they are expected to be temporary and localized. In addition, project specifications indicate that water will be sprayed on roads to reduce fugitive

4.1.2 Operation

During operation of the AFGD system, both overall emissions and ground-level concentrations of SO₂ will be reduced. When the AFGD system is not in operation and during normal conditions

and will be within existing Bailly Station emission permit requirements as discussed below. Thus, no additional impact to that currently prevailing will be observed. The area is currently classified as an attainment area with respect to SO₂. During operation total NO_x emissions will remain unchanged, although concentrations of NO_x at ground level may increase as a result

of the lower temperature of the plume in plume dispersion. SO₂, NO_x and PM₁₀ even with conservative emission rate estimates and without subtracting the contributions of the existing stack from the background concentrations.

Operation of the AFGD system may slightly increase fugitive emissions in the area. This would be due to material handling (imestone, hydrated lime, gypsum) and associated stack draft. However, the small increase in fugitive emissions should not cause any discomfort to visitors to the National Lakeshore or to residents of nearby communities. This will be assured by

shown in Table 4.1-1. As can be seen from this table, the IDEM, CAN, has a level limit on CO. This is to protect and permit

in Section 6.2 Compliance Monitoring (Class II Monitoring).

4.1-1

INDIANA

ADVANCED F
PROJECT

PERMIT LIM
2

IONS

ystem

Permit Limits

1.2

NONE

0.22

40

TA

RE AIR,

ERATING
DESULFUR

SYSTEM I

Statio

Permi

Existin

SO₂ (lb/

NO_x (lb/

Particu
atter

(lb/M

Opacity

Avera

The AFGD system will reduce the SO₂ emission rate by 90

source performance standard (NAPS) and AFGD system permit level of

0.10 lb/MMBtu, respectively. The wet limestone slurry does not react with the NO_x so no NO_x is removed in the SO₂ absorber.

No additional particulate matter is expected to be emitted as a

is no net increase in particulate matter as measured before and

The AFGD system opacity levels are expected to be slightly higher than existing levels, in particular during cold weather. The

moisture content of the stack plume. However, the expected permit limit of 40 percent opacity will not be exceeded.

The AFGD system will be available to process all of the flue gas from the Bailly Station on a continuous basis. This will be accomplished by continuing to pass the Station's flue gas through

the AFGD system or during start-up or shutdown of the AFGD system, the Station's flue gas will flow through the electrostatic precipitators and the existing stack.

Land resources or use impacts during the 24-month construction period are projected to be minimal, primarily as a result of the

industrial state.

Storage in cause a small waterway in immediate area.

Surface dressing will be removed from the site for disposal in an appropriately-approved landfill.

The construction phase will have a minimal effect on the recreational land area adjacent to the Bailly Station. The National Lakeshore will be shielded from construction activities by the "green belt." The green belt is a 300-foot "L" shaped

owned by Northern Indiana, has been left in its natural state to serve as a buffer zone. The Bethlehem Steel Plant to the south and west should also be unaffected by construction because of its industrial environment.

There will be no impact of construction activity on historic

construction site, proposed for inclusion in the National Register of Historic Places, will not be impacted by construction activity.

4.2.2 Operation

Land use impacts at the Bailly Station as a result of AFCD system operations will be minimal since operations will be taking place on a heavily industrialized site.

Part of the AFCD system is facilitating negotiations between Northern Indiana and manufacturers of wallboard to allow Northern Indiana to become a

Alternatively, the gypsum could be landfilled at an existing permitted disposal site. Although this latter disposal option would consume less than 4 acres of land annually, assuming disposal of 220,000 tons in 20-foot lifts, use of an existing appropriately-permitted landfill would result in minimal

County that are appropriately permitted and that have their own approved environmental monitoring programs that they are responsible for.

The quantity of fly ash generated at the Bailly Station with the AFCD system will be slightly higher than that generated by existing operations as a result of the WES in the Unit 8 ductwork. If beneficial uses for the fly ash are not determined, it will be landfilled in an appropriately-approved facility. This

waste disposal and would have been used for normal Station ash

4.3 WATER RESOURCES IMPACTS

4.3.1 Groundwater

4.3.1.1 Construction

The construction of the AFGD system at the Bailly Generating Station will not have any effect on the groundwater in the area. There will be no materials used during the construction period that are expected to cause any problem with groundwater.

Any construction-related oil spills will be quickly contained by soaking into the soil's surface dressing. If necessary, the affected surface dressing will be removed from the site for disposal in an appropriately

4.3.1.2 Operation

The AFGD system will be designed to minimize wastewater generation. However, there will be wastewater from the

discharged to the wastewater system at the Bailly Station per modification of the Station's NPDES permit.

Solid wastes (e.g., ash and potentially gypsum) generated from operation of the AFGD system may be put to

will be stored in silos prior to use in the AFGD system, and fly ash will be stored in a silo prior to removal from the Bailly Station. Thus, the impact on groundwater should be minimal.

4.3.2 Surface Water

4.3.2.1 Construction

A review of the area wetlands indicates that the AFGD

4.3.2.2 Operation

Lake Michigan will provide all process water and meet

with other withdrawals from Lake Michigan, such as the

designed to comply with NPDES permit conditions according to IDEM OWM. The relevant existing and new discharges

in Table 4.3-1.


The Bailly Station currently has discharge through two outfalls to Lake Michigan and several internal outfalls as follows and shown on Figure 4.3-1

- ° Outfalls 001 and 002 are to Lake Michigan and consist of the total plant discharge, which is mostly once through condenser cooling water discharged at Outfall 001. Outfall 002 is an intermittent discharge in cooling water, but generally is not needed.

in-plant causing the discharge to be intermittent. Outfall 301 (boiler blowdown) also contributes to the main Outfall 001.

thence the ash ponds. Other waste streams contributing to the ash ponds are the discharge from recovery, air heater wash, and precipitation on the surfaces of the ponds.

Parameter	Unit	Reported Value	Permit Limit (mg/l)	Notes
001 (Main Outfall)	mg/l	221.1	221.1	
Grease	mg/l	<30	<30	
	mg/l	<15	<15	
	mg/l	29.0	29.0	
	mg/l	241.8	241.8	
	mg/l	24.6	24.6	
	mg/l	0.4	0.4	
201 (Sewage)	mg/l	0.00	0.00	
Uniformity (100ml residual volume)	%	11	11	
TS	mg/l	0.4	0.4	
Station Discharge System Wastewater Permit Limits (mg/l)		Report 30 (100)	30 (100)	
		15 (20)	15 (20)	
		30 (40)	30 (40)	
		394 (400)	394 (400)	
		52 (100)	52 (100)	
		1.4 (2.0)	1.4 (2.0)	
Station Discharge System Wastewater Permit Limits (mg/l)		Report 30 (45)	30 (45)	
		- (400)	- (400)	
		- (2.0)	- (2.0)	




Pure Air

 a joint venture company
**ADVANCED FLUE
 GAS DESULFURIZATION**

**BAILLY STATION/AFCD SYSTEM
 WASTEWATER FLOWS**

Figure 4.3-1

- Outfall 100 is an emergency bypass of the ash ponds of certain low volume wastestreams (floor drains, filter backwash, and water treatment water).
- Sanitary wastewater (201) is treated by an activated sludge plant with chemical coagulation capability, sand filtration, and effluent chlorination. Coal pile run off (Outfall 003) is allowed to discharge to the ground according to the existing wastewater discharge

The AFGD system will have domestic sewage wastes and process related wastewater. The domestic sewage wastes will be routed through the Bailly Station's existing

system prior to combining with the Station's recirculating water. Thus, the AFGD system will impact Outfalls 001 (main outfall) and 201 (sewage

As can be seen from Table 4.3-1, for the parameters which

concentrations still will be within IDEM, OWM permit limits. In addition, additional monitoring requirements

be imposed for the Station/AFGD system combined discharge at the main outfall (001). IDEM, OWM permit requirements

4.4 ECOLOGICAL RESOURCES IMPACTS

4.4.1 Construction

Construction activity related to development of the AFGD system is [REDACTED] systems. The area proposed for construction is presently free of

wildlife will result from increased human activities. This impact may be observed on the less mobile species such as amphibians, reptiles and small rodents, and to a lesser degree on avian

erosion and sedimentation control methods.

4.4.2 Operation

operation.

No state or federally listed threatened or endangered plant or animal species, or critical habitat for such species, are present on the Bailly Station. Also, based on the DOE consultation with the U.S. Fish and Wildlife Service, no special status species are expected to be negatively impacted by the proposed project within the site area.

The AFGD system will conform to the requirements of the NPDES

aquatic resources are expected.

4.5 SOCIOECONOMIC RESOURCES IMPACTS

4.5.1 Construction

An assessment of the relative impact of the construction of the
of the area. The construction work force for the system will
consist of up to approximately 400 construction employees at the

Experience from previous projects indicates that most of the
workers will commute to the job site. This suggests that a number
of workers may come from within Porter County and adjacent
counties. A permanent work force up to 30 to 35 full-time
employees will be required once the AFGD system is operational.
This will contribute to an improved employment outlook in Porter
County.

relatively small percentage of employees requiring permanent

4.5.1.1 Transportation

Primary access to the proposed construction site will be from U.S. Route 12 and the nearby interstate highway system. The anticipated increase in traffic volumes averaging from 100 to 200 vehicle trips per day will easily be accommodated by the existing transportation network. Vehicles associated with construction of the AFGD system will be requested to enter the Bailly Station property from the west on U.S. Route 12 in order to avoid facilities. This will further minimize impact. The lack of residential and commercial enterprise in the area will further minimize impact on the community as a result of construction activities.

4.5.1.2 Noise

sound

result in Noise

site, where the majority of construction activity will occur, is such that the closest residence is approximately 8,400 ft (1.6 miles) away. At this distance, there will be a significant attenuation in the levels of construction noise at the nearest residential receptor.

4.5.1.3 Visual

4.5.2 Operation

The impact on population, employment and housing as a result of operation of the AFGD system will be positive for Porter County and the region surrounding the Bailly Station. Permanent employees of Pure Air will require housing, but will not place a large demand on the real estate market.

4.5.2.1 Transportation

The addition of from 110 to 120 vehicle-trips on a 24-hour basis will not impact the existing vehicular

1500 ... will ... the Bailly Station

will be easily accommodated on-site on a permanent basis. place 96Ti 0 T sensitive 0828 0 TD 3 T2100 0506 Tc -0.8 Tww

4.5.2.2 Noise

Because of the industrial nature of the Bailly Station

net increase in area noise will be imperceptible. The results of an area sound level survey conducted in

Station area vary from approximately 47 to 63 dBA, depending on location. Sound levels in the area as a result of AFGD system operation are expected to increase less than 1 dBA. As indicated, this level is considered

4.5.2.3 Visual

The AFGD system will be perceived as visually blending with the other structures on-site at the Baily Station. The only exception may be the new stack that will be required for operation of the system. The new stack height will be approximately 480 feet or less to ensure a successful and environmentally sound operation. Operation of the

4.6 ENERGY AND MATERIALS RESOURCES IMPACTS

4.6.1 Construction

During the construction phase of the AFGD system heavy construction equipment as well as construction materials such as steel, cement

be other AFGD

existing utility generating station. Temporary structures and

and gypsum will be the by-product from the AFGD system. The raw materials to be consumed and gypsum produced for this project have been estimated as follows:

Estimated Annual Consumption

Coal 1,300,000 tons/yr

Estimated Annual Production

Gypsum 220,000 tons/yr

Estimated Average Consumption

Electrical usage 8.25 MW

Projected Emergency Consumption

The annual estimates are based on an estimated capacity factor of

The average and emergency water and electricity consumption estimates are based on the AFGD system design coal with a 4.51

Limestone will be used as an absorbent. It is inexpensive and

Hydrated lime will be used intermittently in the AFGD system to

occur infrequently system estimates at one every 1 hrs 92 min 01/17/74. 1w (to)

hydrated lime is readily available throughout the United States

Lime is produced in the United States by the burning of limestone

in the United States. The AFGD system

SECTION 5.0

PROJECT MITIGATION MEASURES

The description of mitigation measures presented below is based on information presented in the EIV and the EA, and reflects current design.

Because the AFGD system will be installed in a heavily industrialized area, no significant Environmental, Health, Safety and Socioeconomic (EHSS) impacts are expected during the construction and operation of the system other than the

program will create permanent employment and produce a potentially saleable

technology applicable at other locations throughout the United States.

no open burning.

The AFGD system will reduce SO₂ emissions to the environment during
during an upset condition, stack emissions will be redirected to the

The AFGD system's limestone and hydrated lime reagents will be stored in silos with big vent filters to minimize fugitive emissions. In

silo prior to removal from the site.

Bulk loading of limestone, hydrated lime and by-product gypsum will be done with enclosed transfer systems, minimizing fugitive emissions from these activities. Trucks transporting limestone, hydrated lime or

on-site emissions to the atmosphere. Fugitive emissions resulting from

5.2 LAND RESOURCES MITIGATION MEASURES

During construction, the primary impact on land use in the immediate area may result from the occasional increase in sound levels resulting

The site is sufficient to absorb parking for the work force in existing and planned permanent parking areas. During operation the increase in

Disposal of ash and other solid wastes will be in appropriately

Finally, compliance with zoning requirements and the remote location of the AFGD system within a highly industrialized area will mitigate any

stormwater collection system, construction areas will be closed and

Small quantities of office waste materials, resulting from normal operations, will be stored in covered containers or trash bins to minimize potential contamination of surface water. These materials will

The ash generated from the AFGD system will be placed in an existing storage silo prior to removal from the site for disposal. Any material

Limestone, hydrated lime and gypsum also will be stored in either silos or a building (hydrated lime and gypsum) to prevent run-off to the surrounding area. Any material spilled around these structures will be

5.4 ECOLOGICAL RESOURCES MITIGATION MEASURES

5.5 SOCIOECONOMIC RESOURCES MITIGATION MEASURES

No mitigation measures are proposed for socioeconomic impacts, since no significant impacts are projected during construction and operation of the AFGD system. The AFGD system is viewed as a benefit to the area's socioeconomic setting.

The generation of electrical power is by nature consumptive of natural resources. A large portion of the SO₂ in the stack gas will be converted to a saleable by-product.

present levels.

SECTION 6.0

ENVIRONMENTAL MONITORING

The environmental monitoring program for the AFGD system addresses the three classes of monitoring during preconstruction, construction, and operation/demonstration phases of the project. These monitoring activities are briefly described below in general terms. More detailed information on

The three classes of environmental monitoring are as follows:

1. Class I Monitoring, Environmental Baseline or Characterization Monitoring

Class I monitoring activities address the environmental

will include measurements of feedstocks (coal, limestone, hydrated lime), operating conditions, information on discharges (air emissions, wastewater, solid waste), ambient environmental

6.0-1	THERN IN ION ADVA ION PRO	Paran	O ₃ , CO ₂ , is-% (Mo Carbon, is-% (S, as rece l/Metals	O ₃	O ₃ , CO ₂ , istribut ctivity	O ₃ , CO ₂ , ctivity	<u>Frequency</u> 1 - During AP and 1 - Dur System Oper Similar Coa APC-200 Tes 1 - Each Coa Different S Content Dur System Oper 1 - During AP and 1 - Dur System Oper Similar Lim for APC-200 1 - During AP Operation
6.0-1	THERN IN ION ADVA ION PRO	Paran	O ₃ , CO ₂ , is-% (Mo Carbon, is-% (S, as rece l/Metals	O ₃	O ₃ , CO ₂ , istribut ctivity	O ₃ , CO ₂ , ctivity	<u>Frequency</u> 1 - During AP and 1 - Dur System Oper Similar Coa APC-200 Tes 1 - Each Coa Different S Content Dur System Oper 1 - During AP and 1 - Dur System Oper Similar Lim for APC-200 1 - During AP Operation
6.0-1	THERN IN ION ADVA ION PRO	Paran	O ₃ , CO ₂ , is-% (Mo Carbon, is-% (S, as rece l/Metals	O ₃	O ₃ , CO ₂ , istribut ctivity	O ₃ , CO ₂ , ctivity	<u>Frequency</u> 1 - During AP and 1 - Dur System Oper Similar Coa APC-200 Tes 1 - Each Coa Different S Content Dur System Oper 1 - During AP and 1 - Dur System Oper Similar Lim for APC-200 1 - During AP Operation
6.0-1	THERN IN ION ADVA ION PRO	Paran	O ₃ , CO ₂ , is-% (Mo Carbon, is-% (S, as rece l/Metals	O ₃	O ₃ , CO ₂ , istribut ctivity	O ₃ , CO ₂ , ctivity	<u>Frequency</u> 1 - During AP and 1 - Dur System Oper Similar Coa APC-200 Tes 1 - Each Coa Different S Content Dur System Oper 1 - During AP and 1 - Dur System Oper Similar Lim for APC-200 1 - During AP Operation

imental
edia

olid

olid

mestone

drated Lime

PUP
LY GENE
D
IRONMEN

ator

APC 00 Test

uring
n Per d

ed fc

ne Sil

FLUE

ITOR

imat
e, V
Ult
, N,
Btu
dia

icle
Gene

ral/

st
th
or

st
th
sed

m

Ironmen Media

sum

sum

sum

-20 Test
ng FGD
ratio with
Used for

D System
th ach
lfu

D System
th ach
lfu

-20 Test

GAS

ING

icity
dure

Water
Size

NET

W

a v t g N r

2

2

c i d

-1

THE
TIO
TIO
TER
MONI

met

als
20, (c
F
ity,
y:
itic
id,
atho
lts,
Ca
le a

Ca
le a

als
I
TC
icht

AB

A
TI
UL
LA

e
0,
0,
d
i
r
L
c
u
0,
,
0,
,
e
r
c
t

L)

TI

in

st

Q

Q

Q

E

C


C

C

A

Environmental Media

Sample ID	Location	Media	Method	Parameter	Unit	Remarks
6-4	AFGD System	Ash	General Ignitab Test, I Method CaCl ₂ , CaSO ₄ ·2	Acidity, TCLP Leaching	Duplicate	AFGD System with Coal Used for Test
6-4	AFGD System	Ash	General Ignitab Test, I Method CaCl ₂ , CaSO ₄ ·2	Acidity, TCLP Leaching	Duplicate	AFGD System with Coal Used 200 Test
6-4	AFGD System	Ash	CaSO ₄ ·2 Sulfide		Duplicate	AFGD System with Each Sulfur Coal
6-4	AFGD System	Ash	CaSO ₄ ·2 Sulfide		Duplicate	Testing with Sulfur Coal



TAB

6.0-1

D)

URE AT
NERATI
DESUL

NORTHE
STATIO
RIZATIO

NDIAN
ANCED
JECT

BAILLY

IE GAS

ENVIR
(CLA

ARACTER
I MONI

ON MO
G)

RING

E
ironmen
Media

Sam
ing Location

Parameters

Measur

W
wewater

System Wastewater
Treatment Facility In

Sulfate

Flow, TSS, Oil

FGD System
With Each
Sulfur
Dial

W
wewater

System Wastewater
Treatment Facility Ef

General/M
id Greas

PH
S

Flow, TSS, Oil

FGD System
With
Dial Used
for APC

W
wewater

System Wastewater
Treatment Facility Ef

Sulfate

Flow, TSS, Oil

FGD System
With Each
Sulfur
Dial

A

A
Emissi

Station Stack

2,
acity,
articula

atter

Analysis,
1992 and

A
Emissi

System Stack With
Operation

Mer Metal
drocarb
distribut
x, SO3/

Merbur
Part
Part

Size
Matter,

FGD System
with
for APC-200

TAB 5.0-1

NORTHERN
STATION
IZATIO
RACTER
I MON

Meta
ticle
ticular
/H2SO4

S03

S03

Meta
ticle
ticular
3/H2SO4

Meta
ticle
ticular
3/H2SO4

S03

g Loc

stem
ation

stem
Oper

stem
atio

AFGD
with
on

AFGD
with

AFGD
r Ve
Oper

men
ia

ssi

ssi

ssi

ssi
as

ssi
as

ssi
as

quenc

Dur
peral
oal l
est

Dur
peral
iffer
oal

Dur
peral
iffer
ontel

Dur
peral
oal
est

Dur
peral
oal
est

Dur
peral
Diffe
Coal

stem
imilar
C-200

stem
ach
fu
Content

stem
ach
fu

stem
imilar
C-200

stem
imilar
C-200

stem
ach
fu
Content

Environmental Media

Air Emission (Flue Gas)

Sampling Location

Before AFGD Absorber Venturi Scrubbers in Operation

Sound

Locations of property and area (including lakeshore)

Footnotes:

APC-200 Fukushima, Japan Daily Generation March, 1991
General/Metal, Pb, Li, A
Radioactivity Mon-222, and
P Test ana

Station during normal

pilot plant test was conducted at AFGD

is of the, Mo, Ni,

consists of -230.

clude As,

AFGD System with Each Sulfur Content

Depending on Sampling Daytime and

Test Center in Operations for the test was conducted

Co, Cu, Cd, Cr, F, Zn.

Radium-226,

AS

G

m

Research gas times

Be, C, S, Si

-210, I

NO, Z

A

FO

20

it, U

g, A

s

C

PURPOSE OF THE TEST IS TO DETERMINE THE EFFECTS OF THE AFGD SYSTEM ON THE ENVIRONMENT

ENVIRONMENTAL MONITORING

FO

20

it, U

g, A

s

C

16

pur

1

2

it

e

cl

2

Footnotes: e-
(Contd)

f- When
moni
envi
sulf
Tabl
prop
WES
oper

g- Air

tra
e a
S,
om
is
al
ent
mir
re
f
con

CONTD)

N INDIA
ADVANC
PROJEC

ZATION
ORING)

TCLP Te
, B, C

ing is
WES.
when t
sulfur
fferenc
ate env
Subsec

s, Ba,

.0-

ORT
TATI
ZATI

ACTI
MO

s th
g:

moni
of
he
ere
tant
prop
coal
lica

Sb

T

E
RA
ES

TAT
(C

d fo

za
er
d
rs
si
es
on
us

lo

L

EV

m f

a
n t
d
ve
s
is

ion of acetic aci
Ni, Phenols, Na,

ne add
Fe, Mn

with the WES, th
ceed with monitor
ing the base or n
parameters indic
results, the pro
her without or wi
then be continge

thout
will pr
s util
for th
alytic.
edia e
ing wi

Mn, Ni, Se, Ag, a

Cu, Pb

C

TAB
IR, F
ING S
FURI
ENVI
ASS I

.0-2
HERN
ON AD
ON PR
ENTAL
NITOR

FL
E GAS

RI

Environmental
Media

Sampling Location

Frequency

id

Param

1 Solid

Bunkered Coal

Daily

Gypsum Storage Area

To Be Determined
By Regulatory Agency
Requirements

h, Bt
ermin
ateri
etals
y, I
y, IC
eachi

dered
Includ
ivity,
ndiana
este

Ash Storage Silo

To Be Determined
By Regulatory Agency
Requirements

egula
anc
Method
ide
act
y,
Reactiv
Leachi
g

AFGD System Wastew:
Treatment System

To Be Determined
By Regulatory Agency
Requirements

atory
ethod of
ct
ty,
Reactiv
Leachi
g

W
T
S
em Solids

ermine
uired
But M
etals,
Igni
Indi
t

Be
gency
spos
enera
orros
CLP T
ethod

Be
gency
spos
enera
orros
CLP T
ethod

Flow	Parameter	Method	Frequency	Location	Notes
Flow	Temperature, Chlorine, Chlorination, Sulfate, Fluoride, Phosphate	Flow, Temperature, Chlorine, Chlorination, Sulfate, Fluoride, Phosphate	Weekly	Residual Frequency of TDS	Flow, Temperature, Chlorine, Chlorination, Sulfate, Fluoride, Phosphate
Flow	BOD5, Residual Chlorine	Flow, BOD5, Residual Chlorine	Weekly	Form, Total	Flow, BOD5, Residual Chlorine
Flow	TSS, Sulfate	Flow, TSS, Sulfate	Weekly	Chloride	Flow, TSS, Sulfate
Flow	TSS, Sulfate	Flow, TSS, Sulfate	Weekly	Chloride	Flow, TSS, Sulfate
Flow	Dissolved Solids, Particulate Matter	Dissolved Solids, Particulate Matter	Weekly		Flow, Dissolved Solids, Particulate Matter
Flow	Dissolved Solids	Dissolved Solids	Weekly		Flow, Dissolved Solids

Environmental Media

Air Emissions

Air Emissions

Footnotes: a-

b-

c-

d-

e-

The frequency of sampling should be considered. The following elements should be analyzed: As, Cd, Cr, Hg, Pb, Se, Tl, Zn.

General Leach test should be performed on the following elements: As, Cd, Cr, Hg, Pb, Se, Tl, Zn.

General Leach test should be performed on the following elements: As, Cd, Cr, Hg, Pb, Se, Tl, Zn.

General Leach test should be performed on the following elements: As, Cd, Cr, Hg, Pb, Se, Tl, Zn.

General Leach test should be performed on the following elements: As, Cd, Cr, Hg, Pb, Se, Tl, Zn.

General Leach test should be performed on the following elements: As, Cd, Cr, Hg, Pb, Se, Tl, Zn.

Location

Station 7 and Inlet FGD System

Chemical Stack

Area of sampling should be considered.

General Leach test should be performed on the following elements: As, Cd, Cr, Hg, Pb, Se, Tl, Zn.

General Leach test should be performed on the following elements: As, Cd, Cr, Hg, Pb, Se, Tl, Zn.

General Leach test should be performed on the following elements: As, Cd, Cr, Hg, Pb, Se, Tl, Zn.

General Leach test should be performed on the following elements: As, Cd, Cr, Hg, Pb, Se, Tl, Zn.

FLUE GAS

DRYING

Requirements

Continuous

Continuous in 1994

Continuous in 1994

Continuous in 1994

Continuous in 1994

Continuous in 1994

Continuous in 1994

TAI
RE /
RAT
ESU
ANCE
(CL

2
TH
TI
TI
NM
MO

2.

2.
rt

by
na

ng
K

ss

C

s
ow

ill
red

the
Hg,

ist:

As,

cho
pr
anc

Area of sampling should be considered.

General Leach test should be performed on the following elements: As, Cd, Cr, Hg, Pb, Se, Tl, Zn.

General Leach test should be performed on the following elements: As, Cd, Cr, Hg, Pb, Se, Tl, Zn.

General Leach test should be performed on the following elements: As, Cd, Cr, Hg, Pb, Se, Tl, Zn.

General Leach test should be performed on the following elements: As, Cd, Cr, Hg, Pb, Se, Tl, Zn.

The frequency of sampling should be considered.

General Leach test should be performed on the following elements: As, Cd, Cr, Hg, Pb, Se, Tl, Zn.

General Leach test should be performed on the following elements: As, Cd, Cr, Hg, Pb, Se, Tl, Zn.

General Leach test should be performed on the following elements: As, Cd, Cr, Hg, Pb, Se, Tl, Zn.

General Leach test should be performed on the following elements: As, Cd, Cr, Hg, Pb, Se, Tl, Zn.

Footnotes: a-

b-

c-

d-

e-

There are no other significant emissions from the facility. The following elements should be analyzed: As, Cd, Cr, Hg, Pb, Se, Tl, Zn.

TABLE 0-3

PURE AIR, NORMAL AMBIENT AIR, AND
 FLUE GAS
 SUPPLEMENTAL ENVIRONMENTAL MONITORING
 (CLASS III)

Environmental Media	Sampling Location	Parameter	Frequency
Sound	Location Station Surround (including Lakeshor)	dB(A), Leq, octave B	1 - Before start-up 2 - After System Start-up ^a
Footnote: ^a -	Sound level start-up survey noise are level survey will start-up, at		For AFGD system start-up. If the survey is conducted during winter (November or Winter) when vegetation and insect activity are low, a second survey will be conducted at the earliest possible date after start-up operations.

2. Class II Monitoring, Compliance Monitoring

Class II monitoring will be the monitoring that is required by

monitoring activities. Supplemental environmental monitoring

The aforementioned classes of environmental monitoring are based on the

classes specified in DOE's document, "Environmental Guidance Manual for

Implementing Class I and Class II Remedial Action Plans" (DOE-11)

Class II (supplemental monitoring). Class I monitoring in this scheme is the same as Class II monitoring (compliance monitoring) used in this EMP; whereas

monitoring) and Class III (supplemental monitoring) monitoring activities.

6.1.1 INTRODUCTION

This category of monitoring involves both environmental and

6.1.2 ENVIRONMENTAL STUDIES

The focus of the baseline environmental studies has been the EIV and EA. As part of the development of the EIV and EA for the AFGD project, existing environmental conditions were described for the several disciplines described in Section 3.0 Existing Environment.

Based on process and other information, predictions were made on the impact of the AFGD project on the area environment and appropriate mitigation measures were developed. The potential impacts and mitigation measures were described in Section 4.0 Consequences (Impacts) of the Project and Section 5.0 Project Mitigation Measures, respectively.

~~6.1.3 OPERATING PERFORMANCE TESTS~~

(Table 6.0-1) Phase Tests will be conducted to identify limitations of the AFGD process and operating parameters that may affect environmental discharge. The information from these tests will be related to historical as

6.1.3.1 Bailly Station Operating Conditions

Several Bailly Station operating conditions will be examined based on existing information. These include primarily those associated with air emissions, wastewater discharges, solid waste disposal, and ESP performance. This information will be compared with information operations.

system. Air emissions are currently monitored for SO₂,

flow, temperature, total residual chlorine, and duration and frequency of chlorination; whereas, at the internal monitoring for the process (see Table 6.1-1) monitoring is for flow, SO₂, total chlorine and total residual chlorine. Additional details are provided on the existing monitoring requirements for air emissions and wastewater discharges in Section 6.2 Compliance Monitoring (Class II Monitoring).

The only process waste generated at the Barry Station is sludge from the FGDs. This sludge is sold to a local contractor for use as a soil amendment.

appropriate data is available during baseline monitoring, it will be incorporated in the monitoring program for

6.1.3.2 Process Operating Conditions

Numerous AFGD operating conditions will be monitored. These will include solid or liquid samples, as appropriate, which will be analyzed for the parameters indicated in Table 6.0-1. The sample media will include

° raw coal;

NOR
STA
IZA

XIS
OF

PUR
BAILLY GENER
DE

BAILLY STA
ERMITS FOR OPER

Permit
Limits

6.0

None

0.22
Once each
during
years
1992C

40 b

amples are analyzed f
ary exemptions are a
wns. During boiler s
d for up to 10 (ten)
ature entering the el
ccurs first. During
is allowed for up to
isting Bailly Station
monitoring, "The fir
another test to be per

Parameter

(lb/MMBTU)

(lb/MMBTU)

articulate Matter
/MMBTU)

city (%)

notes: a

b

c

FLUE

M, OF
CONTR

FACILI

Monit
Method/

g
dunked
coal, o
has a

None

EPA Met

EM, St

sulfu
g boi
from t
ods o
r rea
mptio
rage
fies
med o
year

ion
Expiration Date

burned
ural
July 1, 1992

, Stack
July 1, 1992

July 1, 1992

sture.
nd
limit is
ue gas
es F, which
opacity
culate
year 1990

1-2

ERN INDIANA
ON ADVANCED FLUE GAS
ON PROJECT

ND MONITORING RE
O NPDES PERMIT M
IFICATION

Measurement
Frequency

Sample
Type

Daily

24-Hr Total

Daily

Continuous

During Discharge of
Chlorine Bleaching Water

Grab

Monthly Report

Hrs

Monthly Report

Frequency

Weekly

24-Hr Total

Weekly

8-Hr Composite

Weekly

Grab

2 x Weekly

Grab

effect from November 1, 198

until midnight March 31,

During the 3-year demonstration period, Indiana-Illinois

6.1.3.3

Environmental Emissions and Discharges

Sound levels, potential solid wastes, wastewater

parameters will include the following.

Sound Levels


- ° sound levels on Bailly Station property and surrounding area (this monitoring activity was

described in Table 6.1-3 during February, April and October, 1989).

Solid Wastes

operation with similar coal used for APC-200 test and

- ° ash from APC-200 test, and during AFGD system



Notes:

1. Figure Not to Scale.

Homestead) Are Not Shown on the Figure.

Pure Air	
ADVANCED FLUE GAS DESULFURIZATION	
Locations	
Figure 6.1-1	1/91

TABLE 6.1-3

PRE AIR, NORTHERN INDIANA
 RATING STATION ADVANCED F
 ESULFURIZATION PROJECT

LEVEL MONITORING STATIONS

Monitoring Station	Location	Monitoring Period	Parameters
1	Station 102 ft	April	Leq, Octave
2	Station 360 ft	April	Leq, Octave
3	Station 102 ft	October	Leq, Octave
4	Station 360 ft	February	Leq, Octave

1-3 (CONT)
NORTHERN IN
TATION ADV
TATION PRO
MONITORING S

JE GAS

ring
ncy

Monitoring
period

February

April

October

October

PUR
ENE
L

AND

es

re

ing

as

ll

ation

Station

existing
ern gr
rest c
down t
50-
ft fro

of A,
nce on

tation

5

A

B

s 1

fr

f c

elc

log

50-

nc

ell

ei

ers

Le

Le

Le

Le

dt

dt

Le

Le

e

ime

e

ime

e

ime

e

ime

Spe

Spe

Spe

Spe

Spe

Spe

Le

Le

Le

Le

Le

Le

Station	Description	Unit	Per	Parameter	Unit
C	Gas	Octo		dB(A), Octave	trum
D	on fl	Octo		dB(A), Octave	trum
E	acros f hill west of east	Octo		Leq, Octave	trum
F	th of It fer outh. assy a ichiga	Octo		Leq, Octave	trum

6.1. NOR STA LIZATI MONI
 D) D) AM RE T/

GAS

ng
yb

RE
ER
DE

BAI

D

n

o

o

o

o

o

o

s

t

er

t

tr

al

Station

C

D

E

F

GAS

ng
yb

RE
ER
DE

BAI

Description

n

o

o

o

o

o

o

s

t

er

t

tr

al

Parameter

dB(A), Octave

dB(A), Octave

Leq, Octave

Leq, Octave

dB(A), Octave

dB(A), Octave

dB(A), Octave

dB(A), Octave

trum

trum

trum

trum

trum

trum

trum

trum

TABLE 6. (CONTI
 PURE AIR, NO
 Y GENERATING ST
 DESULFURIZ
 SOUND LEVEL MON
 RING S

Station	Description	Monitoring Period	Frequency	Units	Parameters
G	80 ft so ence, th n south ill. Cr bout 100	Oct	curving D area of small tation	dB dB	ve ve nd Spectrum nd Spectrum
H	cross fr estern g	Oct	c from	dB dB	ve ve nd Spectrum nd Spectrum
I	bout 100 ntrance n Cowles rea.	Oct	e Acres ngs Road) ing flat	Le Le	ve ve nd Spectrum nd Spectrum

B)

- a - The sound level in February
- b - The monitoring period per month
- c - dBA measurement used to calculate the average
- d - Sound level center frequency 8,000 Hz
- e - For the measurement and end of

TABLE 6.

PU
GENE
PUND

ing
to 18

cy var
for bo
secor
valent

ts wer
31.5,

ions,
rded
ated s

CONT

N IN
ADV
PRO

NG S

s du
ctob

rom
y tim

erva
d le

e fo
25,

owes
a l
ng.

IA
D FLUE GAS

ONSA

1989 were as
9 to 31.

to two times f
d nighttime.

or 20 minute p
or Leq.

e octave band
500, 1,000, 2

weighted sound
ute period at

station

ere

with
000 and

dba)
nning

Wastewater Discharges

Bailly Station Sewage Treatment Facility Discharge
Outfall 002 prior to AFGD system start-up, and

AFGD system wastewater before and after wastewater

Air Emissions

° Bailly Station stack before AFGD system start-up;

° Flue gas before AFGD system absorber vessel without

° Flue gas before AFGD system absorber vessel with WES

For both the monitoring of wastewater discharges and air
emissions, the sampling methods and types will be the same as

parameters selected for monitoring are based on the following:

1. Parameters which are not required to be monitored by regulatory agencies;
2. Parameters which have been analyzed in similar studies;
3. Parameters which are analyzed as part of the APC-200 test and

4. Parameters that could be affected in various environmental

6.1.4 SCHEDULE

6.1.4.1 Duration

Environmental characterization sampling will be initiated before start-up of the AFGD system and will continue for the 3-year demonstration period, depending on the environmental media to be sampled as follows:

- February, April and October, 1989: Sound Surveys on
- March, 1990 through January, 1991: APC-200 test and analyses with coal, limestone, ash and gypsum.
- Spring, 1990 to Spring or Summer, 1992: Barry Station
- Summer to Fall, 1992: Raw hydrated lime sampling, and
- Summer, 1992 (Startup) through 3-Year Demonstration Period: quarterly environmental collection.

6.1.4.2 Frequency

Environmental characterization sampling will be conducted once during an APC-200 test before AFGD system start-up for coal, limestone, gypsum and ash. Similar sampling will occur for these media and hydrated lime, one time during AFGD system

during the 6-year demonstration period, these tests will be analyzed once each for SO₃ and % S. Sound levels on Bailly Station property and the surrounding area will be determined once prior to start of construction of the AFGD system. Bailly Station operating data (air emissions and wastewater

with and without the WES in operation, also when the system is

content coals are used, wastewater at various locations will be monitored once each for sulfate; air emissions at select

SO₂/H₂SO₄ with and without WES in operation; gypsum will

operation of the WES. It should be noted that the proposed

possibility when different sulfur content coals are used, that

Compliance monitoring will consist of monitoring required by monitoring required will be defined by the AFGD project's permits. Environmental permitting began with the initiation of the development of the EIV in the Fall, 1988. This was followed in the Spring, 1989 when work was begun on obtaining air emission and wastewater discharge permits. Environmental permits were obtained prior to the start of construction. Other environmental permitting activities which were not required prior to the start of construction during the design and construction phases of the project, but may not be completed until the AFGD system is in operation. Environmental monitoring requirements based on contact in Table 6.0-2.

6.2.2 PERMITS AND CONDITIONS

Currently it is expected that there will be three major permits for the AFGD system which will have the following conditions: (1) Permit for Construction of Air Pollution Control Facilities, (2) Permit for Operation of Air Pollution Control wastewater (domestic sewage and process wastewater). In addition, the Bailly Station's existing permit for Operation of Air Station's stack will be used when the AFGD system is not in operation or during an upset condition. Copies of the existing

Permit for Operation of Air Pollution Control Facilities, the AFGD
system's Permit for Construction of Air Pollution Control

the discharge of wastewater, are included in Appendix A. Details
of the conditions of the permit for construction of the
solid waste disposal.

6.2.3 MONITORING REQUIREMENTS AND ENVIRONMENTAL MEDIA

6.2.3.1 Air Emissions

Compliance Monitoring for Air Emissions: Because
operation of the AFGD system will involve air emissions

stacks as discussed below and shown in Tables 6.1-1 and
6.2-1. As indicated in Section 4.2 Atmospheric Resources

Station's flue gas will flow to the existing stack.

limits shown previously in Table 6.1-1. As can be seen
from this table, the IDEM, OAM has placed limits on

TABU

B
PURE AIR, M
GENERATING ST
DESULFURIZ

AFGD SYSTEM
PERMIT LIMITS FOR
AIR POLLUTION

Permit
Limits

1.2

N/A b,c

None

0.22

40

N/A b,e

Monitoring
Frequency

Continuous

Continuous

None

Once within
30 days of
AFGD system
start-up and
once during
94 d

Continuous

Continuous

Concentration

/MMBTU)

/MMBTU)

/MMBTU)

Total Matter
/STU

(%)

(%)

Monitoring
Location

Downstream

Downstream

None

Upstream

Upstream

Downstream

Permit
Expiration Date

-a

-a

None

-a

-a

-a

6.2 CONTD)

NO INDIANA
ADVANCED FLUE
PROJECT

EM, OAM
INSTRUCTION OF
DL FACILITIES

April 4, 1990.
18 months after
Indiana on March
of 1-year or

is used for inf
ru the AFGD sy

ucted in the n
ration System
he first 180 d
h the WES in s
testing with
8 shall be in
n alternative each u
operation of t
ement no long

er to allow co
it limit or lb

revoked
permit

s

ck with
If the
ana has
e WES
r

mit
pt
0)

na
s)
n s
rti
ys
on
be
sy:
ie:
n (

6.2

NO
ST/
RIZA/
STE/
FO/
N C

ativ
will
err
a p

st
is
no

be
er f
al
tate
per
7
an
d).
s r

ir
the

PUR
ENE
DI
A
MIT
R PC

was
com
d b
inu

abl
g f
%

ing
Wa
op
a
ana
Bot
te
eat
d t

s r
uni

s
t
r
ch
t
f
l
l
t
e
j
e
r

a -
b -
c -
d -
e -

Footnotes:

permit limits for NO_x. SO₂ emissions are calculated from bunkered or as burned coal, or natural gas sulfur content. A stack test for particulate matter is required once every 2 years; whereas, opacity is monitored

operation of Air Pollution Control Facilities is in effect until July 1, 1992, Prior to this expiration date,

IDEM, OAM.

Station permit, IDEM, OAM has placed limits only on

Unit 7 and 8 ducts. In addition to these monitoring requirements and permit limits, the IDEM, OAM requires the following:

- ° Particulate matter emissions from each of the limestone and hydrated lime bin vent filters shall be limited to 0.02 grains per dry cubic

roadway flushing program, and

maximum sulfur content of 0.3 percent.

Rationale for Air Emissions to be Monitored. The Bailly

emissions from the new stack, emergency diesel generator

and material handling. The rationale for emissions monitoring requirements are discussed below.

The Bailly Station currently has air emissions monitoring

based on the station's current permits, during the 3-year demonstration period, monitoring will continue for SO₂.

The AFGD system is not expected to change from current

requirements for these two parameters as are currently

more extensive monitoring requirements for these parameters.

The air emissions from the AFGD system's emergency diesel

emissions from materials handling are below the PSD

source.

6.2.3.2 Wastewater Discharges

with 100% effluent flow to approach permitting the AFGD

TABLE 6.2-2

NORTHERN INDIA
STATION ADVANC
RIZATION PROJEC

ITEM PERMIT LIMIT
WASTEWATER DIS

Daily
Maximum

Outfall/Parameter

Outfall 001 (Main

Flow (MGD)

Temperature (°F)

Total Residual Chl
Grab

Duration of Chlora

Chlorination Frequ

pH b

Chloride b

Total Dissolved So

Sulfate b

Fluoride b

E G

MO
S a

sur
equ

Date

Date

Dur

Chl

Mon

Mon

2 x

2 x

2 x

2 x

2 x

sch

Bea

epc

epc

y

y

y

y

y

ite

ite

ite

ite

stewater

(CONTD)

DIANA
ANCED FLUE
JECT
IMITS AND
DISCHARGES

ABLE
NOF
STA
RIZA
TEM
R WAS
t Li

BA
Y S
R

1/P
ameter

1 2
(Sewage
treatment)

MGD

mg/

Col
form (per
100 ml)

Res
idual Chlor
ine (mg/

4
(AFGD S
stem Dis

MGD

B/l

4 Grease (mg/

de
ng/l)

Dis
olved Sol
ids (mg/l)

e
(ng/l)

de
ng/l)

NG

ment
ncy

ly

ly

ly

ly

ly

ly

ly

te

te

te

te

te

- Footnotes: a - The NPDES pe
- b - The indicate from Outfall
- c - Report indic information
- d - N/A indicate appl

BAILL

M STA REQ

was paramet to 0 that has appl

B

E 6 -2 (0

IRTI IN INDI ADVANC PROJEC

IT LIMI WATER DI

and ex ed only limits M, OMM

NG

ght August 31, 1993.

ge of AFGD system process water

ed parameters and the

At the internal Station Outfall 201 (sewage treatment plant), the IDEM, OWM will continue requiring monitoring for chloride, total dissolved solids, total suspended solids, and fluoride.

Because of the addition of an internal discharge from the AEGD system's wastewater treatment system, the IDEM, OWM will require monitoring for pH, temperature, total suspended solids, total dissolved solids, sulfate, and fluoride.

Depending on the parameter, wastewater generally will be

chloride, total dissolved solids, sulfate and fluoride at Outfall 001, are applicable only during periods of discharge from Outfall 401

Rationale for Wastewater Discharges to be Monitored:

Operation of the AEGD system at the Bailly Station will

sanitary sewer wastes that are similar to those to be

Outfall 401, process water from the AFGD system, will be

predicted wastewater characterization of key parameters
submitted to IDEM, OUM by the project. Also, IDEM, OUM
discharge (outfall 001) to Lake Michigan based on the
addition of the discharge from Outfall 401.

6.2.3.3 Solid Wastes

Compliance Monitoring for Solid Waste: Operation of the
three wastes: ash, gypsum, and wastewater treatment
system solids

the Station does not analyze the ash.

If gypsum from the AFGD system is disposed in a landfill,

Similar requirements are expected for the wastewater
treatment system solids.

Rationale for Solid Wastes Monitoring: As indicated above, the monitoring activities for solid waste were

necessary, in appropriately approved facilities which have their own approved environmental monitoring programs that they are responsible for.

6.2.4 SCHEDULE

6.2.4.1 Duration

Compliance monitoring will be initiated as part of start-up activities and will continue through the commercial operation of the AEGD system. However, only

one year of monitoring data (Summer, 1994 to Summer, 1995), will be provided to DOE per the Cooperative Agreement.

6.2.4.2. Frequency

The frequency of compliance monitoring for various parameters is based on the permit conditions for air emissions, wastewater discharges and solid wastes. The frequency of sampling is described in Tables 6.0-2, 6.2-1 and 6.2-2. The frequency for the general categories is summarized as follows:

- Wastewater Discharges: Daily, two times weekly,

- Solid Waste: To be determined by regulatory agency

materials are delineated. There may not be any.

9.2 SUPPLEMENTAL ENVIRONMENTAL IMPACT MONITORING (EIM) AND MONITORING

The necessity for supplemental environmental impact monitoring

determined

Environmental Assessment, and (2) evaluates the need to monitor

6.3.2. MONITORING PREDICTED IMPACTS

The area in which the Bailly Station is located is highly industrialized. Thus, impacts other than in the immediate

Therefore, the planned environmental characterization and

supplemental monitoring be addressed in more detail than shown in

6.3.4 SUPPLEMENTAL MONITORING MEDIA

The AFGD project will be constructed and operated in accordance with all applicable governmental rules and regulations. This will

and the utilization of good engineering practices to protect workers

environmental and occupational monitoring activities. Therefore, it is believed that the compliance and environmental

after AFGD system start-up. All of the stations described in Table 6.1-3 and shown in Figure 6.1-1 will be monitored. At each of these stations, daytime and nighttime sound level measurements will be taken for the same parameters shown in Table 6.1-2.

taken at these two stations.

will be conducted before and after AFGD system start-up. If the after start-up survey is not conducted during a time (fall or winter) when vegetation and insect noise are less likely to interfere with sound level measurements, a second after start-up

consistent with AFGD system operations.

Following the supplemental sound level monitoring, the sound level data

attenuation features will be considered for the AFGD facility. The 5 dBA action level is based on a level which project team members believe, based on extensive sound level survey experience, can be accurately measured by a sound level meter.

report preparation. The quality assurance/quality control program will begin with determining the best locations to obtain representative samples. Sample collection procedures will then be defined and

laboratory is involved, they will receive appropriate samples. The

Agency-EPA, certification), if appropriate, and a within laboratory quality assurance/quality control program. The laboratory will use EPA or IDEM approved analytical methods. Typical approved analytical methods for the majority of the parameters which are expected to be analyzed as

6.4.1 AIR EMISSIONS MONITORING QA/QC PROGRAM

pursuant to Indiana Administrative Code (IAC) and EPA

The QA/QC program for the CEMs or collection of air emissions monitoring will include the following, which may vary depending on the gas or instrument being calibrated:

TABLE 6.2-3

PURE AIR, NORTHERN INDIANA
 BAILLY GENERATING STATION ADVANCED FLUE GAS
 DESULFURIZATION PROJECT

POTENTIAL CHEMICAL AND PHYSICAL
 PARAMETERS TO BE ANALYZED AND ANALYTICAL TECHNIQUES

<u>PARAMETER</u>	<u>ANALYTICAL TECHNIQUE/METHOD</u>
------------------	------------------------------------

Ag, Sr, V, Zn	
---------------	--

Hg, Ti	AA
--------	----

Ga, As, Cd, Pb, Mn, Ni	ICAP/EC
------------------------	---------

Ni, K, Se, U	
--------------	--

CO ₂	Nonindispersive Infrared Analysis
-----------------	-----------------------------------

TCLP Test	40 CFR Part 261 Appendix II
-----------	-----------------------------

Flow (Makeup Water and Wastewater)	In-Line Flow Monitors
------------------------------------	-----------------------

Formaldehyde	Direct Reading (11007)
--------------	------------------------

Indiana Neutral Leaching Method Test	Indiana Solid Waste Management Board Rules and Regulations
--------------------------------------	--

Mean Particle Size	20 Minimum per Sedigraph 5000D Plus Sieve Analysis
--------------------	--

Oil and Grease	40 CFR, Part 136
----------------	------------------

Opacity	CEM
---------	-----

TABLE 6.2-3 (CONTD)

~~GUIDE AIR - NORTHERN INDIANS~~

POTENTIAL CHEMICAL AND PHYSICAL
PARAMETERS TO BE ANALYZED AND ANALYTICAL TECHNIQUES

<u>PARAMETER</u>	<u>ANALYTICAL TECHNIQUE/METHOD</u>
Particulate Matter	40 CFR 60 Appendix A, Method 5b or 17
pH	pH Meter and Electrode
Phenols PM-10	Gas Chromatography/Mass Spectrography
...	...
...	...
SO ₂	40 CFR 60 Appendix A, Method 6c or 19
...	...
SO ₃ /H ₂ SO ₄	Controlled Condensation
Solid Dissolution Procedures	Nitric Acid-Hydrogen Peroxide Dissolution; Lithium Borate Fusion
Specific Surface Area	4-Point BET Analysis
TDS, TSS	40 CFR Part 136
Temperature	Thermometer
Unburned Hydrocarbons	EPA Method 25A

<u>tr</u>	<u>MC</u>	<u>id</u>	<u>03</u>	<u>is</u>	<u>Ca</u>	<u>is</u>	<u>a</u>	<u>1/</u>	<u>ct</u>	<u>id</u>	<u>03</u>	<u>st</u>	<u>03</u>	<u>is</u>	<u>,</u>	<u>at</u>	<u>03</u>	
ab	PU	N	BAILLY GEN	INDIANA	ADVANCED FLUE GAS	PROJECT	SAMI	ETH	AND PHYS	FRAN	CHEMICAL	TO BE MONITORED	-200 Test	Composite of Three Samples	ed	Composite of Three Samples	APC-200 Test	Composite of Three Samples
ate Volatiles, timate d, O, u/lb dry),	C	D	e eral/	H	L	Outlet	Composite of Three Samples											

(CONTD)

ERN INDIANA
ON ADVANCED FLUE GAS
ON PROJECT

FOR CHEMICAL
RS TO BE MONITORED

ethc

Samp

hres]

Composite

APC-200 Test

hres]

Composite

out and with MES
For Different
ent Coal

hres]

Composite

-200 Test

le

R,
NG
FUR

ME
PAR

am

um

um
pe
fur

Fr

BAILLY GE

SA
AND PH

s
(TD)

-2H₂O,
ides),
tivity,
lity,
ng
C,
ing
ater
article

H₂O,

activity,
lity,
ing Method Te

e S

I

m

era
O₃-
O₃ Fr
ros
cti
rac
ced
ian
hod
ubl
e

m

O₄, S

era
ros
cti
ian

BAILLY GE...
D FLUE GAS

SAL...
MONITORED

Sampling Method

Rate of Three

Rate of Three

Rate of Three

BAILLY GE...
AND PHY...

SAL...
AND PHY...

Parameters
(CONTD)

Rate of WES

Rate of WES in

Rate of WES in
For
Coal

Parameters

SI M

General
Method
S04-2
Activity, TCLP
Leaching
activity,
Cl2,

General
Method
S04-2
Activity, TCLP
Leaching
activity,
Cl2,

S04-2
Sulfide

le 6
 IR, C
 NG S
 FURI
 MET
 PAR
 P
 Y GE
 SAM
 D PHY

LE GAS

TARED

d

Sample

Sample

Parameters

ING (CONTD)

Water
 Oil
 Flow
 Solids, NO₃
 General/Met
 Temperature
 Chlorine
 Chlorine
 Date

Grab
 Continuous
 24 hour cc
 Continuous
 Continuous
 Grab durir
 chlorine t
 Report
 Report
 24 hour cc

arge of
water

e St	<u>atic</u>	<u>Sampling Method</u>
I M	nt Pl	24 hour total
11 2	Disch	8 hour composite
w		Grab
5		24 hour composite
al C		Grab
Syst		24 hour composite
ity		Grab
eral		24 hour total
fate		
Oil		
w		
miss	Stac	

P
 MILLY GEN
 SAM
 AND PHYS

(CON

ERN I
 N AD
 N PR
 FOR
 S TO

ANA
 ED FL
 T
 ICAL
 MONIT

Disch

nt Pl

24 hour total
 8 hour composite
 Grab
 24 hour composite
 Grab
 24 hour total

Stac

(CONTD)

IN INDIANA
ADVANCED FL
PROJECT

OR CHEMICAL
TO BE MONIT

ing Method

sis

Emission Mon

1-5

5/IITM-001

25A

Factor (EPA M

7 Series

Emission Mon

S

Coal

Cont

EPA

EPA

EPA

Casc
201)

EPA

Cont

k and Combin
FGD System

tion

ILLY
P
E

AI
Y
AND

ple Stream/Par
eters

SS I MONITORING
(CONTD)

O₂

Capacity

articulate Matte

Emissions from
System without W

ir metals f

unburned Hydrocar

article Size Dis
tribution

O_x

O₂

ble
 AIR,
 ING
 LFUR
 G ME
 PAR
 AND PH
 SA
 AND PH

BAILLY GE
 AND PH

-4 (CONTD)

RTHERN INDIANA
 TION A VANCED FLUE GAS
 TION P OJECT

DS FOR CHEMICAL
 TERS TO BE MONITORED

St	Locat on	Sam	Method	Amplif	Method
	em Stac and inlet D cts to	D Sy bine D Sy	ondensat	ondensat	
			ITM-001		
			5A		
			ector (EP)		
			Series		
			mission		
			ondensat		
	on Bai ly Station nd Surrounding Area National Lakeshore)	atio pert clud	General Radio 700 Precision ating Sound - L and Analyzer w 1962-610 Micro del 1560-P42 Tified or equal		

Spectrum

tion (PM-10)

Stream/Parameter	Sampling Method
MONITORING	
Solid	ASTM D2234-86
% Ash, Btu/	Composite of Three Samples
Determined Material, al/Metals, sivity, Ign sivity, TCLP al Leaching	Composite of Three Samples
Determined y Requireme	Composite of Three Samples

ing Method

f Three
Accordance
blication
elines

Com
Sam
wit
SW-

JE GA S

DRI D

ND
TA
J
CH
B
on

wa

le
IOR
TA
ZA
HO
ME
ple

ste
ht

PURE
GENER
DE
SAMPL
PHYSIC

s
of

metri

G (l

In
Rad
ita
Te
Me

nt

By
nts
y I
Rad
ita
Te
Me

ea

ON

B
Me
ity
Le

T

te
eq
, Me
ity
Le

Sam

CLA

Liq

Di
G
C
R
N

Was

T
A
L
G
C
R
N

Tab

PURE AIR, N
LY GEN RATING S
ESULFURI
SAMPLING MET
D PHYS CAL PARA

Sampling Method

Main Dis

Sewage

Sampling Method

Side

ded from Pump Curves

ious

Composite

ious

Composite

(CONTD)

INDIANA
ADVANCED FLO
PROJECT

CHEMICAL
TO BE MONIT

IN

Water Tre
ment

Stock

m/Parat

ITORING

Wastew
luent

crease

TSS, T

crease

TSS, T

IS from

od

e

e

amp

inuc

our

inuc

our

File Str	Parameters	Sample	Method
S II	NG (CONTD)	Coal Analysis - ASTM	
2	acidity	Continuous Emission Monitor	
	rticulation	EPA Method 5	
	Emission No. 8	Continuous Emission Monitor	
	acidity	Continuous Emission Monitor	
	Emission No. 8	Continuous Emission Monitor	
	2, % (Continuous Emission Monitor	
	Emission	Continuous Emission Monitor	
	2, % (Continuous Emission Monitor	
	rticulation	EPA Method 5	

PL
LY GEN
SAMI
D PHYS

Tab
G S
URI
MET
ARA
amp

JE GAS
DRED

No. to
No. Du
Sys

ined

ameters

NG (CONTD)

ter

m Unit No.

m Unit No.

m AFGD Syst

2

ter

Sample Sta

CLASS III

Sound

dBA, Le

Footnotes

.2-4

ERN
ON AC
ON PR

FOR
RS TC

ocat

Bai
l Sur
ation

lowil
Ni,

gros
-230

Cd,

st is
foll
d ph

LLY GE

SA
ND PHY

am

consi
Li, P

analys
adon-22

yses i

l Leac
he ana
de as

a

I

e

G C a R r T I a N

Samp

Type 1
1988
Integ
Meter
Model
Micro
1560
or eq

Ba, B, Be,
SO4, Sulfide

ta, lead-210,

and Ag.

without the
l, Cu, Cn, F

ethc

1 Ra
Pre
Sou
naly
- 98
and
pre-

, C
Sn,

ium-

on c
Mn,

el
h
er

o, Cu,
V,

c acid
nols,

(CONTD)

6.2-4

Ta

ATHERN
TION AI
TION PI
IANA
NCED FLUE GAS
ECT

DS FOR
TERS TO
EMICAL
E MONITORED

ree individual
ly spaced time
o analysis.

u, Pb, Mn, Ni, Se, Ag,

consists of at l
at approximately
ch are combined in

, As, Ba, Be, Cr,

AIR,
ING
LFUR

G ME
PAR

S permit
are ta
od and

wing:

SE

SA
HY

e
s
s

e - A 24 hour
flow-propo
intervals

f - Air metals
and Zn.

- Documentation of all work on appropriate forms;
- Automatic system calibration check and data adjustment by computer system typically every 24 hours;
- Manual calibration of monitors or analyzer using a calibration gas (SO_2 , O_2/CO_2) or standard (opacity) per criteria for initiating calibration;

- Monitor or analyzer drift determination and adjustment;

Chart recorders;

- Scheduled maintenance program including checking panels, extractive systems, filters, lines and pump assemblies;

bi-weekly calibration of appropriate monitoring data;

- Quarterly cylinder gas audits;
- Annual relative accuracy test audit;
- Initiation of corrective action when either the monitors/analyzers are out-of-control or the routine QA/QC checks indicate that there is a problem with a monitoring system, and

6.4.2 WASTEWATER DISCHARGES MONITORING QA/QC PROGRAM

Methods for ensuring quality assurance and quality control of

wastewater sampling will be incorporated into the standard methods

required to be an approved EPA laboratory and to participate in

- Annual analyses of spiked water samples from EPA containing

NPDES permit;

outside source for evaluation of parameters in the NPDES permit;

- Routine QA/QC testing consisting of analyzing duplicate

including review with Bailly Station Manager and Chief

- QA/QC audit on outside laboratory.

6.4.3 SOLID AND SOLID WASTES MONITORING QA/QC PROGRAM

OSHW's "Waste Sampling Guidelines" and "Laboratory Analysis

expected to follow the procedures outlined in these documents and to have its own QA/QC program. The program will have the following general characteristics:

- Participation in performance evaluation studies as a means of comparing analytical results;

◦ The use of written analytical methodologies that allow

maintenance of service contracts on critical pieces of instrumentation;

- Control charts for routine chemical analyses;
- Periodic submission of internal check samples for routine analyses, and

◦ The use of bound notebooks to record research activities and

6.4.4 SOUND LEVEL MONITORING QA/QC PROGRAM

The QA/QC program for sound level monitoring will focus on the

used during the October, 1989 sound level survey.

During the October, 1989 survey, sound level measurements were taken with a Type 1 General Radio Model 1988-9700 precision

integrating sound level meter and analyzer, Model 1962-9610 microphone and Model 1560-P42 preamplifier. A General Radio Model GR1987 Minical 1 KHz sound level calibrator was used to calibrate

the sound level meter. The sound level meter was calibrated at 94 dB before and after the measurement period.

meter and analyzer battery were checked before and after each measurement period. All measurements were taken with the microphone approximately 5-ft above the ground surface, at a 70° angle above the horizontal towards the noise source. In addition, meteorological conditions were observed and recorded for each

with a cup anemometer. Throughout the measurement period, wind

The purpose for conducting industrial hygiene monitoring is to

designing and engineering controls and operating procedures to limit exposure, and periodically measuring control effectiveness

The scope of the requirements are limited to the hazards that developing these requirements, it is assumed that the potential

in operation, the industrial hygiene monitoring requirements may be modified.

6.5.2 EVALUATION CRITERIA

The Occupational Safety and Health Administration (OSHA) has

not law but are recommended guidelines by the American Conference

Most exposure criteria such as the OSHA PELs and the ACGIH TLVs

repeatedly, during an 8-hour day, 40-hour week, for a working lifetime without adverse health effects.

The chemicals and exposure limits of interest for the AECB process

<u>Chemical</u>	<u>Source</u>	<u>Exposure Limit</u>
(calcium carbonate)	total dust	10 mg/m ³
	respirable fraction	5 mg/m ³
	ACGIH (TWA)	
	total dust	10 mg/m ³
	ACGIH (TWA)	
	ACGIH (TWA)	2 mg/m ³

Calcium sulfate	OSHA (TWA)	
	total dust	15 mg/m3

	total dust	10 mg/m3
--	------------	----------

Noise	OSHA (TWA)	90 dBA
	OSHA Hearing	
	Conser. Amend. (TWA)	85 dBA

In those cases where exposure levels are not the same, the more stringent standard will be used to evaluate the measured exposure.

6.5.3 EXPOSURE MONITORING

the type and number of samples to be taken, as well as the

Sound level measurements and personal noise dosimetry measurements will be obtained. Hearing protection will be required for all employees working in areas where sound levels exceed 85 dBA.

established. Affected employees will receive annual audiograms and hearing conservation training. Noise exposure assessments

PRINCIPLE ENVIRONMENTAL PLANNING VIEWS REPORT

LABORATORY QA/QC

OTHER INDICATORS

MANAGER ENVIRONMENTAL PROJECTIONS REPORT

QA/QC REVIEW

ENVIRONMENTAL SPECIAL INVESTIGATIONS REPORTS QA/QC

MONITORING TEAM DATA

ANALYSIS APPROPRIATE

MONITORING TEAM SAMPLES

NO

ENVIRONMENTAL REPORT

ENVIRONMENTAL OPERATIONAL REPORT

ENVIRONMENTAL OPERATIONAL STATUS REPORT

MONITORING REVIEW

LABORATORY ANALYSIS IF APPROPRIATE

MONITORING TEAM SAMPLES

DOE OPERATIONAL REPRESENTATIVE

ENVIRONMENTAL PROJECT MANAGER REPORT

ENVIRONMENTAL REVIEW

MONITORING TEAM SAMPLES

CC TECH

P

ENVIRONMENTAL CHEMIST COORDINATOR AND REPORT PREPARED BY LABORATORY QA/QC

RE 7.1-2 ENVIRONMENTAL AND REPORT PREPARED FOR AFGD PROJECT

MONITORING TEAM DATA

MONITORING TEAM SAMPLES

DOE

ENVIRONMENTAL

OPERATIONAL

REPORT

STATUS

REVIEW

ANALYSIS

SAMPLES

DOE

ENVIRONMENTAL

LABORATORY

During Phase 1, activities associated with environmental monitoring

will be analyzed for various parameters indicated in Table 6.0-1. In addition, the gypsum and ash generated from the tests will be analyzed for the parameters shown in Table 6.0-1.

7.2.2 PHASE 2 - CONSTRUCTION AND START-UP

This phase of the project also will involve minimal environmental monitoring. As indicated in Table 6.0-1, prior to start-up, hydrated parameters. Also, Table 6.0-3 indicates that sound level measurements

PHASE 3 - OPERATIONS AND MAINTENANCE

6.0-1, 6.0-2 and 6.0-3 will be conducted during this project phase. Monitoring will be conducted by both Pure Air and/or Northern

the Arab system will allow for the collection on a routine basis of and the Arab system.

Emission information will be collected from a monitoring system that system. Additional emissions information will be provided by

7.3 MONITORING MEDIA

The environmental media to be monitored include solid, liquid, and gas streams. Tables 6.0-1, 6.0-2 and 6.0-3 summarize the sampling points,

Monitoring samples or data initially will be collected by either a Pure Air or a Northern Indiana Monitoring Team (Figure 7.1-2). If appropriate, samples will be sent to a laboratory for analyses. The

management personnel for review before being transmitted to DOE via Pure Air's Project Manager. Throughout the collection of samples, analyses discussed in Section 6.4 Quality Assurance/Quality Control Program.

SECTION 8.0

DATA MANAGEMENT AND REPORTS

A Data Management System will be implemented in order to maintain

Data Management System will establish a consistent procedure for data

reviews and checks will be done into the data management system by

Continuous Emissions Monitors (CEM's) will be stored on a personal
computer (PC). Other data collected will be stored in hard copy form in

Resources for processing data will include experienced members of the

Environmental Programs Department may be used in assimilating data and
reports.

8.2 REPORTING SCHEDULE

During Phase 3 of the project, environmental monitoring status reports

As previously described in Section 6 Environmental Monitoring, there are
three classes of environmental monitoring associated with the AFGD

project. During the period of Class I Environmental Baseline or Characterization Monitoring, the parameters listed in Table 6.0-1 will be examined. Results of the APC-200 test will be documented after completion of the study, and summarized in the first quarterly report

Results of these monitoring activities will be provided with the first yearly report.

A number of parameters collected (e.g., air emissions, wastewater

quarter throughout the demonstration period. The data collected as part of AFGD system operation, which are not routinely collected at the Bailly Station, will be summarized in a quarterly report as soon as possible and detailed in an annual report.

When Class II Compliance Monitoring begins, the gathered data will

years.

The data generated from the sound surveys conducted during Class III Supplemental Monitoring will be summarized as part of a quarterly

8.3 FORMAT AND CONTENT OF MONITORING REPORTS

reports with comments concerning compliance and data characteristics when

(Class II Monitoring), and 6.0-3 (Class III Monitoring). The analytical techniques and methods used in collecting samples have been listed in

TO BE AS FOLLOWS:

I. Overview of Quarter or Year

II. Project Status

B. Wastewater Discharges

C. Solid and Solid Waste Discharges

1. Products and By-products

D. Plant Operations

IV. Compliance

A. Compliance with Permit Limits

B. QA/QC

V. Problems and Recommendations

A. Compliance with Permit Limits

D. Modifications to Sampling or Analytical Methods

E. Other Miscellaneous Support for the Report

The contents of the report sections are briefly described below:

system operation will be discussed and the monitoring activities

8.3.2 SECTION II PROJECT STATUS

project will be described. This will include a description of the AEGD system process conditions for that quarter and the

AEGD system operation for the next quarter also will be

8.3.2 SECTION III SOURCE EMISSIONS AND DISCHARGES

Monitoring data for the various environmental media will be summarized in this section of each quarterly report and detailed in the annual report. Emphasis will be placed on air emissions

described below.

8.3.3.1 Air Emissions

Each report will contain a table of emissions (opacity, percent of O₂ or CO₂) will be collected and stored on a PC with backup data recorded on strip charts. These data will be reduced and accessible via the PC. The SO₂ content of coal at the Bailly

appropriate station personnel. This information will

and archived. All of the data discussed above will be

laboratory will be received by the Station's
Environmental Operations Specialist or Air Monitoring

Coordinator for retention.

Various parameters monitored with respect to wastewater discharges will be processed and reported at different intervals according to the Bailly Station operating permits. All of the data will be accumulated and organized in the reports similar to that reported to the Indiana Department of Environmental Management, Office of Water Management. A similar format will be used when makeup water monitoring is conducted.

analyses of ash, gypsum, wastewater treatment system solids, and other solid materials (e.g., coal, limestone, hydrated lime). The reporting of these data will be similar to that used for reporting air emissions or wastewater discharges laboratory data. Data from a laboratory will be initially forwarded to Northern Indiana's Environmental Operations Specialist or the Pure Air Monitoring Team. It then will be reviewed and incorporated in a report for further review/dissemination by appropriate project personnel.

8.3.3.4 Plant Operating Conditions

Detailed descriptions of plant operating conditions

the time of a particular monitoring activity or when the WES is being tested.

8.3.4 SECTION IV COMPLIANCE

An evaluation of compliance with applicable permit limits will be included in each report. Excursions, if any, will be discussed in relation to AFGD system operations.

An integral part of determining compliance will be an evaluation of the QA/QC procedures. As shown in Figure 7.1-2, QA/QC checks will be performed at least two times on data as it passes through the Northern Indiana and Pure Air

project team hierarchy's of data management and reporting.

8.3.5 SECTION V PROBLEMS AND RECOMMENDATIONS

After commenting on monitoring data quality and discussing any problems with Bailly Station or AFGD system operations, the quarterly and final reports will include a section where recommendations will be made to rectify problems. Even if there are no problems during the demonstration period, improvements in operations may become apparent and will be summarized or discussed in this section of each report.

8.3.6 SECTION VI APPENDICES

reports, the project will deal with this request on a case-by-case basis. Pure Air may not allow some process information to be released to the public, however, if necessary, in order to evaluate the performance of the project, the DOE Contracting Officer's Technical Representative

Information is forwarded to the CUR, the information will have

information at PRC ATR's headquarters.

MHI has an extremely strong United States patent position both in the

overall FGD process as well as in specific areas of process technology.

This involves significant MHI proprietary information which has been

provided to the CUR (overall FGD test data) to the DOE but not to the EPA.

The types of process information considered proprietary include the

environmental monitoring reports.

The types of process information considered proprietary include the

patent

The types of information that are not considered proprietary include the

- ° flow rates of materials and stream temperature entering and leaving the overall process, and each major process step (e.g., consumption of coal, limestone and other feed streams),

- quantitative information on composition and flows for the existing Bailly Station streams for which the percent SO₂ can be calculated, and emissions of additional parameters (e.g., particulates);
- frequency of replacement of reagents or equipment since this can have major impact on process costs;

within individual process steps only where the magnitude of the recycle streams is important to environmental monitoring;

this 0.52.0887 Tw (streams) Tj0 Trf63.2336 0
is a significant consideration in the commercial potential of the process and environmental monitoring (e.g., where size

SECTION 9.0

LIST OF PREPARERS AND PROFESSIONAL
QUALIFICATIONS

9.1 AIR PRODUCTS AND CHEMICALS, INC.

Environmental Engineering Design for Air Products and Chemicals, Inc. Process System Group. He has over 20 years of industrial experience in chemical and refinery technology, process engineering, and environmental assessment, control and permitting. He has contributed to the published literature in the areas of environmental control and water and wastewater treatment, and is a recipient of the Harrison Prescott Eddy Medal from the Water Pollution Control Federation.

Reighard, Robert C., B.S. Ch.E.

Mr. Reighard, a Chemical Engineer, is the Director of Operations for Pure Air. He has over 20 years of industrial experience in PVC plant design, construction and maintenance; H₂, CO, O₂, N₂ and Ar industrial gas plant design, operation and maintenance; coal gasification technology;

desulfurization plant design. For 10 of the 20 years Mr. Reighard held positions as Plant Engineer and Plant Manager.

9.2 NORTHERN INDIANA PUBLIC SERVICE CO.

Ross, John M., B.A., M.B.A.

Mr. Ross is the Superintendent of Environmental Planning in Northern

Indiana's project coordinator for the preparation of AFGD project

air monitoring system design and operation, estimation of air pollution

involved in the analysis of environmental regulation and policy to the

9.3 PURE AIR

Bolinsky, Francis T., B.S.

Brown, Gregory N., B.S.

Mr. Brown, a Process Engineer, is working on the process design for the

Heydorn, Edward C., B.S., M.S.

Mr. Heydorn, a Process Engineer, is the Principal Process Engineer for the AFGD project. He has over 10 years experience in the design and operation of industrial chemical facilities.

Mr. Brown, a Chemical Engineer, served as a Process Engineer for

and private utilities. Mr. Brown is a Registered Professional Engineer

Dennis, D. Steve, B.S., M.S., Ph.D.

Dr. Dennis, an Environmental Project Supervisor, coordinated the overall development of the FMP. He has over 10 years experience with

industrial projects throughout the United States.

APPENDIX A

BAILLY GENERATING STATION AND AFGD PROJECT ENVIRONMENTAL PERMITS

- BAILLY GENERATING STATION PERMIT FOR OPERATION
OF AIR POLLUTION CONTROL FACILITIES

- AFGD SYSTEM PERMIT FOR CONSTRUCTION OF AIR
POLLUTION CONTROL FACILITIES

BAILLY GENERATING STATION
PERMIT FOR OPERATION OF
AIR POLLUTION CONTROL FACILITIES
(DATE ISSUED APRIL 5, 1989)

Indianapolis, Indiana 46225

Northern Indiana Public Service Company
Bailly Generating Station
at Burns Harbor
Chesterton, Indiana

is hereby authorized to operate

the cyclonic (subcritical) coal fired boiler (Unit #7), rated at 1638 million

precipitator. Controlled boiler emissions are exhausted to the atmosphere through a 400-foot tall stack having a 15-25-foot exit diameter through a

Conditions:

1. That the data and information supplied in the application shall be considered 2-1-1. this change must be approved by the Office of Air Management.
2. That the equipment shall be operated and maintained in accordance with the manufacturer's specifications.

Expiration Date July 1, 1992

Issued by April 5, 1989
James W. Kuck
Commissioner

Conditions Continued:

4. That pursuant to 326 IAC 6-2 Section 1(b), particulate matter emissions to the atmosphere

5. That pursuant to Section 4 (e) of 326 IAC 2-1, stack tests to determine particulate matter

1992. The Office of Air Management (OAM) shall be notified of the test dates in advance pursuant with 326 IAC 3-2-3, and test reports shall be submitted to the OAM within 45 days

(Note: Analysis based on composite samples for weekends and holidays will be acceptable.)
The above analysis will include all of the following on an as bunkered or as burned basis: heat

of the quarter shall be submitted by the last day of the month following the end of the quarter.

8. That visible emissions shall be limited to 40% opacity pursuant to 326 IAC 5-1, Section 2(a)(1), for attainment areas.

occurrence. This report shall also include the total accumulated periods of excess

10. That at no time shall the combined rate of heat input for Boiler Nos. 7 and 8 exceed a total of

**OPERATION PERMIT
OFFICE OF AIR MANAGEMENT**

Control No. 2015

Page 1 of 2

Indianapolis, Indiana 46225

Northern Indiana Public Service Company
Bailly Generating Station
at Burns Harbor
Chesterton, Indiana

the cyclonic (critical) coal fired boiler (Unit #8), rated at 3374 million

through a 100 foot tall stack having a 107.5 foot exit diameter that is shared
with Unit #7.

This permit is issued under provisions of 326 IAC Article 2 with the following
conditions:

1. That the data and information supplied in the application shall be considered

2. That the permittee shall comply with the provisions of the Indiana Environ-
mental Management Law (IC 13-7), Air Pollution Control Law (IC 13-1-1)

Manufactured & Specified

Identification No. 64-07-92-0246

Date Issued April 5, 1989

Burns Harbor, Indiana

Conditions Continued:

That pursuant to 326 IAC 6-2-3, Section 1(b), particulate matter emissions to the atmosphere

pursuant with 326 IAC 3-2-3, and test reports shall be submitted to the OAM within 45 days of the test.

6. That pursuant to 326 IAC 7-1-21 (a)(2), sulfur dioxide emissions from Boiler Nos. 7 and 8 shall be limited to 6.0 lbs./MMBtu. Boilers 7 and 8 shall be fired with coal, fuel oil or natural gas.
7. That the station shall sample and analyze the coal used in Boiler Nos. 7 and 8 on a daily basis (Note: Analysis based on composite samples for weekends and holidays will be acceptable.)

Records of the daily average sulfur content, heat content and sulfur dioxide emission rate (in

8. That visible emissions shall be limited to 40% opacity pursuant to 326 IAC 5-1, Section 2(a)(1), for attainment areas.

granted to allow, when necessary, the following visible stack emissions during boiler startups and shutdowns.

(a) During boiler startups an exemption from the 40% opacity limit is allowed for up to 15 minutes after the electrostatic precipitator reaches 250 degrees F, which ever occurs first. In the event that the above is exceeded due to special circumstances (such as a cold startup after an outage) the station shall report this to the OAM within 48 hours of the occurrence.

(b) During boiler shutdowns an exemption from the 40% opacity limit is allowed for up to 15 minutes after the boiler is cooled to 250 degrees F, which ever occurs first. In the event that the above is exceeded due to special circumstances (such as a cold startup after an outage) the station shall report this to the OAM within 48 hours of the occurrence.

For 1992, the station shall maintain the combined rate of heat input for Boilers Nos. 7 and 8 exceed a total of 1,000,000 lbs./hr.

Indianapolis, Indiana 46229

Chesterton, Indiana

This permit is issued under provisions of 326 IAC Article 2 with the following conditions:

1. That the data and information supplied in the application shall be considered

7-1-1992

Expiration Date July 1, 1992

Issued by *James W. Keener*
Commissioner

Northern Indiana Public Service Company

Chesterton, Indiana

is hereby authorized to operate

the facilities associated with the fuel and dry flyash handling and storage systems, serving the coal fired boilers.

This permit is issued under provisions of 326 IAC Article 2 with the following conditions:


~~That the data and information supplied in the application shall be accurate~~
in an increase in potential emissions exceeding those specified in 326 IAC 2-1-1, this change must be approved by the Office of Air Management.

3. That the equipment shall be operated and maintained in accordance with the manufacturer's specifications.
4. That fugitive dust emissions shall comply with 326 IAC 6-4.

Identification No. 64-07-92-0248

Date Issued April 5, 1989
AL

AFGD SYSTEM PERMIT FOR
CONSTRUCTION OF AIR
POLLUTION CONTROL FACILITIES
(DATE ISSUED MARCH 15, 1990)



105 South Meridian Street
P.O. Box 6015
Indianapolis 46206-6015
Telephone 317-232-8603

TO: All Permittees

FROM: *Ally*
Director, Method

OFFICE OF PERMIT MANAGEMENT

SUBJECT: Standard Permit Conditions

1. Pursuant to IC 13-7-10-2.5(b), IC 4-21.5-3-5(f), and IC 4-21.5-3-5(h).

petition for stay or effectiveness are filed, any part of the permit within the scope of the petition for stay is stayed an additional 15

RECEIVED

MAR 20 1990

ENVIRONMENTAL DEPT.

An Equal Opportunity Employer

CONSTRUCTION PERMIT

Control No. 772

Page 1 of 6



NORTHERN INDIANA PUBLIC SERVICE COMPANY
BAILLY GENERATING STATION
NEAR CHESTERTON, INDIANA

is hereby authorized to construct

the Advanced Flue Gas Desulfurization (AFGD) system at the above location. This

units / and a live gas stream, along with associated material handling and storage

THIS PERMIT IS ISSUED UNDER PROVISIONS OF RULE 326 IAC 2-1 WITH CONDITIONS LISTED

Identification No. PC (64) 1816

Expiration Date N/A

Date Issued 3/15/90

Issued by Thomas J. Mitchell

Commissioner

Advanced Flue Gas Desulfurization System
PC (64) 1816

Construction Permit Conditions

1. That this permit to construct does not relieve Northern Indiana Public

2. That the data and information supplied with the application shall be

3. That the equipment shall be installed in accordance with the manufacturers

5. (a) That pursuant to 326 IAC 3-1-8(1)(B), instruments for continuous monitoring and recording of AFGD system sulfur dioxide outlet emissions shall be installed. The outlet monitor shall be located in the new AFGD

be used for informational purposes only to provide data on % SO2 removal thru the AFGD scrubber.

monitoring and recording of outlet percent oxygen or carbon dioxide (necessary to convert sulfur dioxide continuous monitoring data to the units

(b) That instruments for continuous monitoring and recording of inlet

scrubber at the location that the inlet sulfur dioxide concentration is monitored. (Note: The inlet monitor is to be used for informational purposes only to provide data on % SO2 removal thru the AFGD scrubber.)

7. That pursuant to 326 IAC 3-1-8(1)(A), instruments for continuous monitoring and recording of opacity from Unit 7 and Unit 8 shall be installed. These continuous opacity monitors shall be located in the individual unit ducts downstream of the ESP's but upstream of the AFGD system combined flow duct in a location that meets the EPA's continuous emission monitor location guidelines. Data from these opacity monitors shall not be combined but recorded and reported separately.

Operation Conditions

Emission Limitations

1. That sulfur dioxide emissions from the AFGD system stack shall be limited to 1.2 pound per million Btu's of energy input. (This rate was used in the

2. That pursuant to 329 IAC 6-2-1(b), particulate matter emissions to the

(b) That instruments for continuous monitoring and recording of sulfur dioxide combined Unit 7 and 8 AFGD scrubber inlet emissions shall be certified, calibrated, maintained and operated. (See Construction condition only to provide data on % SO2 removal thru the AFGD scrubber.)

(b) That instruments for continuous monitoring and recording of combined Unit 7 and 8 AFGD scrubber inlet percent oxygen or carbon dioxide (necessary

monitor is to be used for informational purposes only to provide data on %

6. That pursuant to 326 IAC 3-1-8(1)(A) instruments for continuous monitoring and recording of opacity from Unit 7 and Unit 8 shall be installed, these opacity monitors shall be located in the individual units ducts

The station shall sample and analyze the coal sampled on a daily basis. The above analysis will include the heat content and %S on an

(initial operation is defined as the first time the AFGD is in operation removing SO₂ from a Unit 7 or 8 flue gas stream) with another test to be conducted during calendar year 1994 (or in the second calendar year following the initial test) of operations which shall be notified of the test dates in advance in accordance with 326 IAC

system and the Wastewater Evaporation System (WES) in service. If the WES

greater load during the test. (As an alternative each unit may be tested

the 20-day rolling weighted average SO₂ emission rate (in pounds per

excluded from the calculation of the daily average but shall be reported on

Conditions Continued:

9. (Continued)

A separate 30-day rolling weighted average shall be maintained for the
AFGD stack and the sulfur dioxide stack. The rolling weighted average shall be maintained for the
which there is a period of more than one hour during which either stack is

Reporting Requirements

10. That pursuant to 326 IAC 3-1-10 reports of the time, duration, magnitude and
cause of periods of excess emissions (as below) or monitor malfunctions
shall be submitted to the OAM on a quarterly basis as follows:

a) all periods of excess (greater than 40%) opacity in percent (%), on a

Btu's on a block three-hour average basis, during periods when the three
hour average outlet SO₂ emission rate exceeds 1.2 lbs/MMBtu's;

- date;

- daily weighting factor (generation or coal burned);

Material Handling Requirements

12. That the limestone to be used in the AFGD system shall be pulverized to the

13. That particulate matter emissions from each of the limestone and lime bin

Advanced Flue Gas Desulfurization System
PC (64) 1816

Conditions Continued:

14. That dewatered gypsum will be transferred via an enclosed conveyor to an enclosed storage building.
15. That the fugitive dust plan as described on pages 5-1, 4-2, and 4-3 of the October 1989 document submitted by Northern Indiana, entitled "Fugitive Dust Control Plan - Addendum to Engineering Report", shall be implemented.
(Referenced pages attached to permit)

Special Operating Requirements

17. That operation of the ARGD system emergency diesel generator shall be limited to 24 hours per month (288 hours per year). Records of all months

Records of all months shall be maintained in a log and the total cumulative operation

FUGITIVE PARTICULATE EMISSIONS CONTROL

Operation of the AFGD system will be Pure Air's responsibility; whereas, Bailly Station operator (including the all fugitive emissions associated with the AFGD system will be the

ascertaining that fugitive emissions associated with the reagent

The Pure Air designated individual will have direct communication

As indicated above, Northern Indiana will be responsible for controlling fugitive emissions from which the Bailly Station's Plant Manager will be responsible for implementing the vehicle resuspension fugitive emissions control plan. The Station's Coal Handling Department will be responsible for carrying out the specific plan activities and for maintaining

permit conditions.

15 ton/yr, respectively) with either 4.5 or 3.0 percent sulfur coal. This is summarized in Table 4-1.

In order to control fugitive particulate emissions from

subside reactivation the following procedures will be implemented

1. The total approximate 3.2 mile roadway shown on Drawing

week basis. Based on a control efficiency presented in the Ohio EPA document entitled, Reasonably Available Control Measures for Fugitive Dust Sources (September 1980), this activity will yield an efficiency of 80 percent emissions reduction.

2. A high pressure water flushing truck such as that manufactured by Klein Equipment, Inc., TX, Model No: D600 will be used to wash the roadway surface.

representative of onsite conditions.

- b. It is raining at the time of the scheduled water flushing.

BAILLY GENERATING STATION/AFGD
SYSTEM NPDES PERMIT
MODIFICATION FOR WASTEWATER DISCHARGES
(DATE ISSUED MARCH 2, 1990)



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

RECEIVED

105 South Meridian Street

VIA CERTIFIED MAIL P 741 219 991

Mr. William R. Elliott, V. P.

Re: NPDES Permit No. IN 0000132
NIPSCO Bailly Station
Chesterton, Indiana

Dear Mr. Elliott

Your application for modification of the above-referenced discharge permit has been processed in accordance with Section 402 and 405 of the Federal Water Pollution Control Act, as amended (33 U.S.C. 1251, et seq.) and the following

itemizes and explains the rationale for the revisions.

The enclosed NPDES Permit Amendment covers your existing NPDES consistent with the terms and conditions of this permit, as amended.

to the final permit.

Request must be filed in accordance with IC 4-21.5-5-7 and IC 13-7-10-5 and must include facts demonstrating that the party requesting appeal is the

requested under the provisions of IC 4-21.5 and IC 13-7-10.5.

An Equal Opportunity Employer

Mr. William R. Elliott
Page 2

If you have questions concerning this modification, please contact

T.P. Chang for

Charles B. Bardonner
Assistant Commissioner
Office of Water Management

MWS/ssh


Enclosure

cc: Chief, Permit Section, U.S. EPA

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
AMENDED AUTHORIZATION TO DISCHARGE UNDER THE
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

NORTHERN INDIANA PUBLIC SERVICE COMPANY
BAILLY GENERATING STATION

December 6, 1988, is hereby amended, as contained herein. The amended provisions shall become effective April 1, 1990. All terms and 9


Charles B. Bardonner
Assistant Commissioner
Office of Water Management

5003p 9/25/89

The discharger has a Class C industrial wastewater treatment plant, classified in accordance with 327 IAC 8-12, Classification of Water and

PART I

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning on the effective date of this permit and

	Quantity or Location	Quality or Concentration	Unit	Frequency	Monitoring Method		
Flow [2]	Report	Report	MGD	--	--	Daily	24-Hr. Total
Temperature [3]	Report	Report	°F	--	--	Daily	Continuous
Total Residual Chlorine+	--	--	--	0.2	mg/l	Daily [5]	Grab
Duration of Chlorination [4]	--	--	--	--	--	Monthly Report	
Chlorination Frequency [4]	--	--	--	--	--	Monthly Report	

[2] Flow may be estimated by engineering calculations.

[3] See Other Requirements, Part III of Permit.

[4] Total Residual Chlorine (TRC) may not be discharged from any single generating unit (condenser) for more than two hours per day. Frequency and Duration of chlorination need only be

[5] During discharge of chlorine bearing wastewater.

The discharge shall not cause excessive foam in the receiving

The discharge shall not contain oil or other substances in

2. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge from Outfall 100 - Miscellaneous Low Volume Bypass. Such discharge shall be limited and monitored by the permittee as

Parameter	Quantity or Loading			Quality or Concentration			Monitoring Requirements	
	Monthly Average	Daily Maximum	Daily Loading	Monthly Average	Daily Maximum	Units	Frequency	Sample Type
TSS	--	--	0.0508	30	100	mg/l	Daily*	Grab
Oil & Grease	--	--	0.0300	15	20	mg/	Daily*	Grab

*During discharge

a. The pH shall not be less than 6.0 nor greater than 9.0. The pH

b. The discharge shall not cause excessive foam in the receiving

amounts sufficient to create a visible film or sheen on the

but prior to mixing with other wastewaters.

<u>Parameter</u>	<u>Monthly Average</u>	<u>Daily Maximum</u>	<u>Units</u>	<u>Monthly Average</u>	<u>Daily Maximum</u>	<u>Units</u>	<u>Measurement Frequency</u>	<u>Sample Type</u>
Flow	Report	Report	MGD	--	--		Weekly	24-Hr. Total
TSS	--	--		20	30	mg/l	Weekly	24-Hr. Comp.

sampling is to be conducted daily.

- b. The discharge shall not cause excessive foam in the receiving and settleable solids.

d. Samples taken in compliance with the monitoring requirements

T. Iron	--	--	--	1.0	mg/l	Daily*	24-Hr. Comp
T. Copper	--	--	--	1.0	mg/l	Daily*	24-Hr. Comp

wastes" means any wastewater (including chemical cleaning liquor,

to boiler tube cleaning, boiler furnace cleaning and air preheater
cleaning. The volume of boiler cleaning waste to which these
limitations apply is two boiler volumes including the initial

40 CFR 423.12(b)(5) as a metal cleaning waste, is to be considered

but prior to mixing with other wastestreams.

<u>Parameter</u>	<u>Monthly Average</u>	<u>Daily Maximum</u>	<u>Units</u>	<u>Monthly Average</u>	<u>Daily Maximum</u>	<u>Units</u>	<u>Measurement Frequency</u>	<u>Sample Type</u>
Flow (MGD)	Report	Report		--	--		Weekly	24-Hr. Total
BOD ₅	--	--		30	45	mg/l	Weekly	8-Hr. Comp.

through October 31 annually. Disinfection is not required, and chlorination should not be practiced November 1 through March 31

<u>Parameter</u>	<u>monthly</u>	<u>Daily</u>	<u>Units</u>	<u>monthly</u>	<u>Daily</u>	<u>Units</u>	<u>measurement</u>	<u>sample</u>
	<u>Average</u>	<u>Maximum</u>		<u>Average</u>	<u>Maximum</u>			
Oil & Grease	--	--		15	20	mg/l	2 X Monthly	Grab

b. The discharge shall not cause excessive foam in the receiving waters. The discharge shall be essentially free of floating

c. The discharge shall not contain oil or other substances in

samples shall be taken at a point representative of the discharge

7. The discharge of the discharge shall be monitored as follows:

DISCHARGE MONITORING PLAN FOR THE PROJECT - SUCH AS FOR THE YEAR

Parameter	Average	Maximum	Units	Average	Maximum	Units	Frequency	Type
-----------	---------	---------	-------	---------	---------	-------	-----------	------

shall be monitored as follows: by a weekly grab sample, during periods of discharge.

b. The discharge shall not contain oil or other substances in

8. During the period beginning on the effective date of this modification and lasting until the expiration date, the permittee is

	Report	Report	MGD	--	--	--	2 X Weekly	24-Hr. Total
Flow	--	--	--	30	100	mg/l	2 X Weekly	24-Hr. Comp
ISS	--	--	--	15	20	mg/l	Monthly	Grab
Oil & Grease								
Chloride								
Sulfate				Report	Report	mg/l	2 X Weekly	24-Hr. Comp
[1]	--	--	--	52	100	mg/l	2 X Weekly	24-Hr. Comp
[2]	--	--	--					
Fluoride				Report	Report	mg/l	2 X Weekly	24-Hr. Comp
[1]	--	--	--					

of these pollutants, after mixing of the effluent of Outfalls 401 and 001. This should be determined by actually measuring these concentrations at Outfall 001, after mixing of all wastestreams. No credit for net discharge will be considered for these pollutants.

a. The pH shall not be less than 6.0 nor greater than 9.0. The pH shall be monitored as follows: by a grab sample twice weekly.

above shall be taken at a point representative of the discharge but prior to mixing with other wastestreams.

c. The permittee is strongly encouraged to exercise the option of

B. MONITORING AND REPORTING

1. Representative Samples

2. Reporting

The permittee shall submit discharge monitoring reports (DMR-1 Form) to the Indiana Department of Environmental Management containing

effective.

Environmental Management for relief from reporting requirements. The Commissioner may then suspend reporting requirements without public notice or opportunity for public hearing.

The Regional Administrator may request the permittee to submit

the number of days during the calendar month when the measurements were made.

(2) Concentration Basis - The "monthly average" concentration

daily determination of concentration shall be the

(1) Weight Basis - The "daily maximum" discharge means the total discharge by weight during any calendar day.

(2) Concentration Basis - The "daily maximum" concentration means the daily determination of concentration for any calendar day.

approximately equally spaced time intervals during a 24-hour period and which are combined prior to analysis.

d. Concentration--The weight of any given material present in a unit volume of liquid, unless otherwise indicated in this

Administrator, U.S. EPA, located at 230 South Dearborn Street, Chicago, Illinois 60604.

The "Guidance" is defined as the Guidance of the Administrator, U.S. EPA, located at the following address: 105 South Maridian Street

The analytical and sampling methods used shall conform to the current version of 40 CFR, Part 136. The approved methods may be included in the texts listed below. However, different but equivalent methods are allowable if they receive the prior written approval of the State agency and the U.S. Environmental Protection

Washington, D.C. 20005.

(2) A.S.T.M. Standards, Part 23, Water; Atmospheric Analysis

(3) Methods for Chemical Analysis of Water and Wastes
June 1974, Revised, March 1983, Environmental Protection Agency, Water Quality Office, Analytical Quality Control Laboratory, 1014 Broadway, Cincinnati, OH 45202.

this permit, the permittee shall record the following information:

d. The analytical techniques or methods used, and

e. The results of all required analyses.

6. Additional Monitoring by Permittee

If the permittee monitors any pollutant at the location(s) designated herein more frequently than required by this permit,

such monitoring shall be reported in the Monthly Discharge Monitoring Report.

All records and information resulting from the monitoring activities

shall be retained for a minimum of three (3) years, or longer, if requested by the Regional Administrator or the Indiana Department of Environmental Management.

C. REOPENING CLAUSE

1. If the U.S. EPA and the State of Indiana find that

the permittee is not in compliance with the discharge limitations for the control of such discharges.

2. If the U.S. EPA and the State of Indiana find that the permittee is not in compliance with the discharge limitations for the control of such discharges.

compliance, if necessary, after final promulgation and effectiveness of revised Indiana Water Quality Standards.

PART II
STANDARD CONDITIONS FOR NPDES PERMITS
FOR INDUSTRIAL FACILITIES

SECTION A. GENERAL CONDITIONS

1. Duty to Comply

Pursuant to the Indiana Environmental Management Act, any person who violates

permit conditions for discharges sections 201, 202, 206, 207, or 208 of the

of such person under this provision, punishment shall be a fine of not more

and "Upsets," Section B, Paragraph 3, nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance.

3. Duty to Mitigate

The permittee shall take all reasonable steps to minimize or correct any

4. Permit Actions

This permit may be modified, revoked and reissued, or terminated for cause.

- c. A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge.

revocation and reissuance, or termination, or (ii) a notification of planned changes or anticipated noncompliance does not stay any permit condition.

5. Duty to Provide Information

The permittee shall furnish to the Commissioner, within a reasonable time, any information which the Commissioner may request to determine whether cause

permit.

6. Duty to Reapply

If the permittee wishes to continue an activity regulated by this permit after

permit expiration date.

7. Transfers

This permit is nontransferable to any person except after notice to the Commissioner pursuant to Regulation 327 IAC 5-2-6(c). The Commissioner may

8. Toxic Pollutants

standard or prohibition) is established under Section 307(a) of the Clean

The permittee shall comply with effluent standards or prohibitions established under Section 307(a) of the Clean Water Act for toxic pollutants (subject to standards or prohibitions) even if the permittee has not yet been required to incorporate the requirement.

9. Containment Facilities

When cyanide or cyanogen compounds are used in any of the processes at this facility, the permittee shall provide approved facilities for the containment of any losses of these compounds in accordance with the requirements of Water Pollution Control Board Regulation 327 IAC 2-2-1.

10. Oil and Hazardous Substance Liability

12. Property Rights

The issuance of this permit does not constitute an acceptance of ownership of any property.

The provisions of this permit are severable and if any provision of this

14. Inspection and Entry

The permittee shall allow the Commissioner, or an authorized representative, upon the presentation of credentials and other documents as may be required by law, to:

under the conditions of this permit:

c. Inspect at reasonable times any facilities, equipment (including

of sample or conduct of laboratory tests, for the purpose of assuring permit compliance or as otherwise authorized by the Clean Water Act

SECTION B. MANAGEMENT REQUIREMENTS

1. Proper Operation and Maintenance

treatment which are installed or used by the permittee and which are necessary

a. Definitions:

- (1) "Bypass" means the intentional diversion of a waste stream from any portion of a treatment facility normally utilized for treatment of the waste stream.

natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production at the permittee's

- (1) bypass is unavoidable to prevent loss of life, personal injury or severe property damage;

(if this information is provided orally, a written submission

Commissioner, if possible, at least ten days before the date of the bypass.

- c. An anticipated bypass which meets the three criteria of Paragraph b

3. Upset Conditions

a. Definition: "Upset" means an exceptional incident in which there is

to the extent caused by operational error, improperly designed

defense to an action brought for noncompliance with such technology

(1) An upset occurred and the permittee has identified the specific cause(s) of the upset, if possible;

and

(3) The permittee complied with any remedial measures required

4. Removed Substances

Solids, sludges, filter backwash, or other pollutants removed from or
manner such as to prevent any pollutant from such materials from entering
waters of the State and to be in compliance with all Indiana statutes and
regulations relative to liquid and/or solid waste disposal.

SECTION C. REPORTING REQUIREMENTS

1. Planned Changes in Facility or Discharge

Any anticipated facility expansions, production increases, or process
modifications which will result in new, different, or increased discharges of
pollutants must be reported by submission of a new NPDES application or, if
such changes will not violate the effluent limitations specified in this

Following such notice, the permit may be modified to revise existing pollutant
limitations and/or to specify and limit any pollutants not previously limited.

MONITORING RESULTS SHALL BE REPORTED AT THE INTERVALS AND IN THE FORM

Reports of compliance or noncompliance with interim and final requirements

- b. Violation of a maximum daily discharge limitation for any of the pollutants listed by the Commissioner in the permit to be reported within 24 hours; and
- c. Any noncompliance which may pose a significant danger to human health or the environment.

A written submission shall also be provided within 5 days of the time the

permittee becomes aware of the circumstances. The written submission shall

6. Other information

If the permittee becomes aware that he failed to submit any relevant facts

information.

7. Changes in Discharge of Toxic Substances

The permittee shall notify the Commissioner as soon as it knows or has reason to believe:

- a. That any activity has occurred or will occur which would result in the discharge of any pollutant identified as toxic, pursuant to Section 307(a) of the Clean Water Act which is not limited in the

(1) One hundred micrograms per liter (100 ug/l);

milligram per liter (1 mg/l) for antimony;

(2) Five (5) times the maximum concentration value established for

(4) The level established in Part III of the permit by the Commissioner.

intermediate or final product or byproduct any toxic pollutant which was not reported in the permit application.

8. Signatory Requirements

- a. All reports required by the permit and other information requested by the Commissioner shall be signed and certified by a person described below or by a duly authorized representative of that person:

(2) For a partnership or sole proprietorship: by a general partner or the proprietor, respectively; or

(3) For a Federal, State, or local governmental body or an agency or political subdivision thereof: by either a principal executive officer or ranking elected official.

(1) The authorization is made in writing by a person described above.

(2) The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, or position of equivalent responsibility. (A duly authorized individual occupying a named position.); and

(3) The authorization is submitted to the Commission

shall make the following certification:

"I certify under penalty of law that I have personally examined

individuals immediately responsible for obtaining the

fine and imprisonment.

9. Availability of Reports

Board Regulation 327 IAC 12, all reports prepared in accordance with the terms

10. Penalties for Falsification of Reports

The Indiana Environmental Management Act provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or

violation, or by both.

Briefing Memo
September 22, 1989

NIPSCO - Bailly Generating Station
246 Bailly Road
Chesterton, Indiana 46304
NPDES Permit No. IN 0000132

Background

The NPDES permit for this facility was renewed September 29, 1988, and

company between Air Products and Chemicals, Inc., and Mitsubishi Heavy

Two wastestreams will be generated by this operation: sanitary wastewater and process wastewater from the scrubber itself. The sanitary wastewater will be discharged to the existing NIPSCO sanitary wastewater treatment plant (STP)

characteristically high in TSS and TDS. Plans are to discharge this wastestream to the cooling wastestream (Outfall 001) for mixing prior to

effluent between the Unit 3 air preheater and the electrostatic precipitator (ESP) where the water would be evaporated and the resultant solids collected.

For the reasons described above, no modification is proposed for the

The permit is being modified to include a new Outfall 401 for the discharge of the treated AFGD process wastewater to the cooling water wastestream prior to its ultimate discharge to Lake Michigan. Effluent limitations are proposed for TSS, oil and grease, chloride, TDS, sulfate, fluoride and pH. A new page 1 is included to reflect this modification. A new page 2 is included to include the requirements for new Outfall 401.

Pollutants

Mo. Ave.

Daily Max.

concentrations as predicted by the permittee. This change has come about due to the ongoing activity surrounding the revisions to the Indiana Water Quality

Waters" (327 IAC 2-1) would apply. The current proposal for revision of

criteria for fluoride.

The actual limitations for these four pollutants apply at Outfall 001,

limitations can really be applied at Outfall 401 for these pollutants.

Expiration Date

This modification will expire August 31, 1993, as with the current permit.

0813B 10/16/89

Post Public Notice Addendum 12-4-89 M.W. Stanifer Revised 3-1-90 JWC

During the public notice period, comment letters were received from the

1. pH monitoring at outfalls 301 and 401 (Pages 7 and 9); The permittee's request is reasonable. Redundant pH sampling is not necessary for outfall

2. Sampling frequency for dissolved solids at 401 (Page 9); the permittee's

operation, if such results demonstrate adequate compliance. Such modification would require public notice.

401 (page 9). IDEM believes that the permit is clear that the limitations for the various dissolved solids and pH are only applicable after mixing with other wastestreams and are not applicable at the point of discharge to the

4. As with comment 2, IDEM will entertain a request to review (and reduce) monitoring frequencies after a period of substantial compliance has been demonstrated. Also, as with the other previous responses, no change has been made in the permit.

5. The permit (page 9) has been revised to clarify that sampling for the parameters prescribed at outfall 401 is required only during periods of

6. IDEM accepts NIPSCO's comments regarding the experimental nature of the

results of the initial test operational period regarding this matter prior to

(1.5 mg/l) was incorrect. The permit limitation of 1.4 mg/l is the correct value. In accordance with agency policy to maintain continuity of the records, the Briefing Memo as drafted has not been altered.

U.S.EPA Region 5 submitted a comment letter dated Jan. 23, 1990 which contained three comments on the draft permit. The Region 5 comments and IDEM responses are summarized as follows:

proposal has been reviewed for consistency with the nondegradation provisions of the discharge on Lake Michigan.

While this subject was touched upon in the original Briefing Memo, it quality of Lake Michigan, so long as the effluent limitations are consistently

2. Region 5 commented that the original Briefing Memo "did not discuss the

be recalculated accordingly. IDEM contends that since the permit intentionally does not provide for net limitations, or credit for quantities of these same pollutants which are present in the intake or from other sources

3. Region 5 noted that the monthly average concentration limit for TDS should be 344 mg/l as stated in the Briefing Memo rather than 394 mg/l. This error has been corrected.

the in